

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 111年08月25日

報表日期: 111年08月25日

項目 單位	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.52	12.21	54.19	0.09	19.18	12.45	1.58	59066.12
1	12.37	7.06	39.99	0.30	21.32	10.32	1.58	71868.52
2	13.10	13.85	37.20	0.54	19.92	10.55	1.58	71254.34
3	12.81	7.14	42.02	0.51	19.83	10.66	1.59	70393.15
4	13.78	2.18	38.32	0.94	18.47	11.14	1.59	67646.95
5	9.77	15.04	35.84	0.47	18.25	11.34	1.59	63910.79
6	11.78	3.88	42.67	0.38	19.88	11.00	1.62	68410.01
7	13.30	4.79	40.56	0.58	18.54	11.10	1.63	67918.56
8	12.20	2.80	40.92	0.50	18.39	11.28	1.60	65946.79
9	12.28	2.43	42.80	0.45	18.40	11.04	1.63	67313.57
10	12.91	7.62	43.18	0.55	18.05	10.86	1.65	67977.38
11	8.22	14.88	34.86	0.79	15.88	11.57	1.61	63020.45
12	12.30	2.21	47.97	0.08	18.62	11.59	1.65	62960.02
13	12.90	3.63	43.39	0.17	18.04	11.29	1.65	65257.95
14	14.52	8.72	49.88	0.40	17.49	11.78	1.65	62556.46
15	12.40	14.40	53.82	0.39	18.37	11.69	1.64	61609.09
16	13.24	0.94	53.86	0.17	18.05	11.74	1.63	62792.56
17	12.89	1.20	41.94	0.60	16.57	11.97	1.65	63051.12
18	12.42	0.60	49.37	0.12	18.91	11.65	1.65	64012.46
19	12.72	0.50	52.32	0.14	19.24	11.09	1.65	67744.94
20	11.95	1.09	57.48	0.12	18.08	12.07	1.66	60611.60
21	13.44	1.26	67.13	0.04	18.26	12.46	1.67	59532.17
22	11.76	0.89	55.83	0.05	18.63	11.92	1.68	62615.07
23	13.69	1.04	48.93	0.11	19.63	11.32	1.67	66135.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.34	5.43	46.44	0.35	18.58	11.41	1.63	65150.24
最 大 值	14.52	15.04	67.13	0.94	21.32	12.46	1.69	71868.52
發生時間	14	5	21	4	1	21		1
最 小 值	8.22	0.50	34.86	0.04	15.88	10.32	1.57	59066.12
發生時間	11	19	11	21	11	1		0
零點偏移(率)	-0.09 %	-0.05 %	-0.04 %	0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	2.15 %	0.91 %	-0.31 %	0.34 %		0.11	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月25日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	4.24	3.62	72.20	0.14	17.30	12.01	1.43	75953.97
1	11.76	6.62	58.26	0.14	19.49	10.26	1.44	89382.86
2	13.24	9.80	64.70	0.82	17.49	10.38	1.43	89563.76
3	12.77	2.74	64.35	0.60	17.15	10.53	1.44	89156.08
4	12.73	1.58	48.69	0.82	17.02	10.74	1.43	88443.53
5	13.92	3.93	49.86	1.21	16.84	10.73	1.43	89008.03
6	14.11	3.64	45.58	0.95	17.44	10.35	1.42	79116.35
7	12.39	6.58	52.94	0.46	17.95	10.38	1.42	91429.72
8	12.31	0.91	66.93	0.22	17.03	11.26	1.43	83669.07
9	11.72	0.48	65.78	0.16	16.97	10.96	1.43	87025.56
10	14.30	4.93	51.09	0.49	15.45	11.38	1.43	83197.63
11	14.36	2.98	56.14	0.27	15.60	11.62	1.46	77971.74
12	12.05	1.21	61.01	0.09	16.96	11.19	1.46	80686.07
13	12.00	1.82	59.35	0.09	16.74	11.05	1.46	83122.09
14	13.40	3.35	54.20	0.34	16.18	11.19	1.46	84694.13
15	13.44	2.53	58.55	0.36	15.88	11.69	1.43	80606.32
16	12.13	1.88	62.34	0.11	17.13	11.45	1.40	79568.89
17	13.09	7.11	62.02	0.51	15.19	11.83	1.42	80160.60
18	12.50	5.51	53.52	0.37	15.39	11.73	1.39	76942.28
19	13.03	2.12	45.25	0.10	17.57	10.87	1.40	84791.23
20	11.97	1.81	44.72	0.08	17.20	10.90	1.41	84499.92
21	12.75	1.36	51.64	0.09	16.96	11.40	1.40	80416.23
22	10.89	1.85	56.64	0.13	15.76	11.71	1.40	77207.15
23	12.28	4.81	61.29	0.14	16.29	11.98	1.40	76102.14
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.39	3.47	56.96	0.36	16.79	11.15	1.43	83029.81
最 大 值	14.36	9.80	72.20	1.21	19.49	12.01	1.48	91429.72
發生時間	11	2	0	5	1	0		7
最 小 值	4.24	0.48	44.72	0.08	15.19	10.26	1.38	75953.97
發生時間	0	9	20	20	17	1		0
零點偏移(率)	-0.10 %	0.00 %	-0.13 %	0.00 %		0.04	0.00	0.00 %
全幅偏移(率)	0.68 %	0.15 %	-0.05 %	0.25 %		0.09	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 111年08月25日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	12.46	11.83	42.05	2.09	18.55	9.93	1.76	75314.88
1	12.01	9.64	45.09	3.14	19.25	8.34	1.75	82821.55
2	14.67	13.92	46.79	3.76	18.59	8.78	1.75	77792.69
3	13.50	13.32	46.96	3.77	15.57	9.65	1.76	72876.93
4	12.24	10.96	47.33	5.95	16.06	9.95	1.76	72901.57
5	13.93	14.82	45.43	3.92	16.87	9.53	1.78	76323.83
6	11.63	11.05	43.84	3.98	15.10	10.05	1.80	70551.97
7	11.80	9.13	45.09	2.26	16.93	10.20	1.73	72078.05
8	12.70	3.28	45.55	2.84	15.72	10.22	1.76	74959.77
9	12.05	1.56	62.20	2.99	16.67	9.98	1.75	73097.76
10	12.83	2.07	62.53	4.12	15.93	10.15	1.79	75733.65
11	16.03	12.60	51.11	3.75	15.66	10.06	1.80	75232.44
12	12.03	4.58	45.54	2.55	16.36	10.14	1.75	70170.68
13	13.40	4.17	53.36	2.54	16.80	10.54	1.75	66992.41
14	18.29	4.04	58.48	3.36	16.59	10.99	1.77	65723.76
15	12.49	4.81	53.68	2.44	17.16	9.93	1.80	72736.01
16	11.61	11.86	55.53	2.42	16.43	10.75	1.74	65983.90
17	12.30	7.37	52.32	3.17	14.86	11.16	1.76	64487.00
18	12.27	1.25	51.37	2.50	16.62	10.19	1.77	72244.48
19	12.42	2.78	43.88	2.47	16.41	10.04	1.75	72714.05
20	12.78	0.55	48.36	2.43	16.76	10.09	1.76	71824.61
21	12.69	0.34	53.09	2.18	18.59	9.97	1.79	71307.69
22	13.15	6.30	44.27	2.12	17.65	9.81	1.80	76078.19
23	12.68	0.44	52.19	2.14	18.91	9.94	1.80	71705.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	13.00	6.78	49.84	3.04	16.84	10.02	1.77	72568.89
最 大 值	18.29	14.82	62.53	5.95	19.25	11.16	1.81	82821.55
發生時間	14	5	10	4	1	17		1
最 小 值	11.61	0.34	42.05	2.09	14.86	8.34	1.72	64487.00
發生時間	16	21	0	0	17	1		17
零點偏移(率)	-0.06 %	-0.00 %	-0.00 %	-0.01 %		-0.02	0.00	0.00 %
全幅偏移(率)	1.60 %	0.13 %	-0.37 %	0.14 %		0.41	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								