

P001_樹林焚化廠CEMS系統日報表-A 報表日期: 111年07月09日

報表日期: 111年07月09日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 111年07月09日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.67	1.86	68.70	0.14	19.15	10.26	1.41	87378.73
1	10.95	5.26	61.85	0.32	17.81	10.58	1.42	87473.73
2	14.22	8.95	53.47	0.61	18.25	10.56	1.41	83670.93
3	11.64	7.52	70.32	0.18	18.69	10.79	1.42	84120.07
4	12.89	1.81	55.54	0.25	19.76	10.15	1.41	88832.67
5	11.58	2.91	65.06	0.14	19.90	9.80	1.38	90025.45
6	11.06	5.33	64.00	0.21	19.21	11.30	1.40	80976.55
7	12.68	3.20	62.60	0.33	19.20	11.15	1.42	81818.97
8	12.27	7.60	73.29	0.15	17.64	12.28	1.43	71546.69
9	10.88	4.70	61.60	0.12	18.09	11.35	1.44	78816.01
10	14.40	13.99	55.37	1.01	16.55	10.75	1.43	86847.86
11	15.87	13.04	56.49	1.79	15.12	11.11	1.43	82804.82
12	14.53	8.56	48.81	1.60	15.42	11.00	1.42	81556.59
13	14.73	1.97	45.03	0.76	16.11	10.84	1.41	82909.78
14	13.80	2.71	48.66	0.45	16.49	10.68	1.42	83292.14
15	13.90	7.36	61.71	0.27	17.58	10.53	1.42	83817.02
16	12.57	2.81	59.43	0.51	16.37	10.86	1.41	81923.60
17	12.77	0.87	65.71	0.12	18.61	10.41	1.42	84232.49
18	13.08	2.00	63.28	0.09	17.94	10.57	1.43	86258.72
19	13.94	2.49	61.52	0.12	17.78	10.77	1.42	86435.46
20	12.28	3.73	60.60	0.17	18.11	10.95	1.43	85627.07
21	9.98	8.40	63.29	0.16	16.78	11.89	1.43	76302.80
22	10.29	10.87	65.65	0.08	16.94	12.56	1.43	71183.76
23	11.12	3.64	50.93	0.10	18.25	11.27	1.43	81656.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.63	5.48	60.12	0.40	17.74	10.93	1.42	82896.18
最 大 值	15.87	13.99	73.29	1.79	19.90	12.56	1.45	90025.45
發生時間	11	10	8	11	5	22		5
最 小 值	9.98	0.87	45.03	0.08	15.12	9.80	1.38	71183.76
發生時間	21	17	13	22	11	5		22
零點偏移(率)	-0.03 %	-0.00 %	-0.14 %	-0.07 %		-0.17	0.00	0.00 %
全幅偏移(率)	3.73 %	-0.08 %	-0.19 %	0.14 %		0.28	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年07月09日

項目 單位	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
0	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
1	14.06	9.43	49.41	2.03	18.48	10.09	1.61	72680.19
2	12.85	12.68	51.48	1.97	17.48	10.69	1.61	68917.15
3	14.48	13.41	51.77	2.78	16.99	10.16	1.62	74133.93
4	13.90	2.66	65.21	2.72	17.90	10.55	1.62	71026.09
5	13.89	3.03	59.86	2.58	17.65	10.41	1.60	70834.50
6	15.32	8.60	51.79	2.46	17.73	9.92	1.61	74904.20
7	13.68	7.44	56.53	2.34	17.40	10.63	1.62	70787.53
8	8.54	2.91	59.63	1.47	19.68	10.44	1.57	70146.01
9	13.43	3.33	53.95	1.67	19.46	9.84	1.55	77734.08
10	13.72	9.73	53.02	1.44	18.99	10.48	1.61	72700.11
11	12.26	14.53	46.92	2.19	17.22	10.14	1.58	75039.23
12	16.48	6.37	47.92	1.99	15.94	10.27	1.55	74566.12
13	13.48	8.47	49.15	1.84	15.70	10.29	1.56	71429.01
14	15.41	7.26	48.46	2.16	15.59	10.14	1.59	71594.86
15	14.59	3.08	46.77	2.06	15.06	10.42	1.59	70278.68
16	16.29	10.40	52.70	2.59	15.17	10.57	1.61	74547.18
17	16.48	8.54	48.62	2.77	15.26	10.44	1.61	70443.50
18	14.24	3.08	51.05	1.63	17.44	10.08	1.59	73579.65
19	15.09	9.02	46.68	1.32	18.20	9.74	1.57	76297.59
20	11.28	5.36	60.38	1.40	17.46	10.32	1.55	78088.18
21	14.39	4.41	54.85	1.49	17.64	10.10	1.60	78843.56
22	10.40	1.68	48.97	1.51	15.98	10.61	1.61	71658.95
23	11.62	2.85	57.52	1.50	17.44	10.54	1.58	69521.33
24	11.60	4.74	56.24	1.57	17.79	10.50	1.57	69451.21
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均 值	13.64	6.79	52.87	1.98	17.24	10.31	1.59	72883.45
最大 值	16.48	14.53	65.21	2.78	19.68	10.69	1.63	78843.56
發生時間	11	10	3	2	7	1		20
最小 值	8.54	1.68	46.68	1.32	15.06	9.74	1.54	68917.15
發生時間	7	21	18	18	14	18		1
零點偏移(率)	-0.06 %	0.00 %	-0.13 %	-0.02 %		-0.35	0.00	0.00 %
全幅偏移(率)	4.84 %	0.09 %	0.15 %	0.19 %		-0.11	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								