

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 111年09月03日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	11.30	3.30	44.80	0.15	18.38	13.11	1.84	54769.96
1	11.52	12.17	58.07	0.13	17.50	14.12	1.89	47705.15
2	10.85	10.87	62.43	0.12	17.31	13.98	1.89	49051.58
3	12.48	5.94	51.90	0.09	18.03	12.24	1.86	61193.07
4	13.45	5.61	42.23	0.11	17.48	11.80	1.87	64491.06
5	3.87	14.27	36.12	0.14	18.28	11.48	1.76	66350.48
6	12.99	5.13	39.12	0.18	18.62	11.85	1.75	61623.38
7	10.07	6.64	50.85	0.16	20.41	12.03	1.78	59974.21
8	11.41	5.89	44.48	0.17	21.47	10.81	1.80	68157.81
9	13.03	3.30	42.17	0.15	20.85	11.10	1.82	67040.14
10	13.29	3.43	40.95	0.10	19.47	11.35	1.82	66085.93
11	11.62	3.76	47.34	0.16	19.79	11.86	1.82	61695.90
12	11.17	4.67	51.26	0.17	19.24	12.57	1.81	57291.09
13	11.28	3.55	42.42	0.17	20.01	11.97	1.82	61467.65
14	12.69	1.15	47.47	0.18	20.48	11.78	1.83	63152.00
15	12.63	1.39	36.79	0.14	19.92	11.21	1.83	66773.40
16	12.55	5.51	36.19	0.12	19.60	11.34	1.83	65013.67
17	12.90	1.19	36.13	0.12	19.73	11.14	1.82	66612.20
18	11.62	1.58	44.26	0.15	20.12	11.63	1.83	62642.50
19	8.31	2.77	52.12	0.17	18.65	12.95	1.85	54717.50
20	9.15	6.78	42.27	0.17	19.30	12.39	1.83	59074.84
21	12.58	4.19	38.71	0.16	19.88	11.61	1.84	64239.49
22	13.04	6.31	37.42	0.13	20.21	10.92	1.85	67861.88
23	12.86	2.97	45.69	0.14	20.15	11.42	1.86	64594.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.53	5.10	44.63	0.14	19.37	11.94	1.83	61732.49
最 大 值	13.45	14.27	62.43	0.18	21.47	14.12	1.93	68157.81
發生時間	4	5	2	6	8	1		8
最 小 值	3.87	1.15	36.12	0.09	17.31	10.81	1.75	47705.15
發生時間	5	14	5	3	2	8		1
零點偏移(率)	-0.02 %	-0.11 %	-0.01 %	-0.04 %		-0.04	0.00	0.00 %
全幅偏移(率)	0.02 %	0.82 %	-0.44 %	0.06 %		-0.17	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 111年09月03日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	12.01	3.69	58.51	0.18	19.26	11.16	1.67	83059.03
1	11.67	4.66	71.54	0.16	17.19	12.74	1.67	71790.79
2	12.59	3.38	59.76	0.13	17.96	11.51	1.68	82268.97
3	12.77	7.90	57.09	0.14	16.41	11.73	1.70	81381.04
4	13.09	1.96	62.63	0.13	17.86	10.95	1.70	87066.35
5	12.78	2.78	68.78	0.14	17.66	11.37	1.70	83264.43
6	17.54	3.29	63.46	0.17	19.55	10.85	1.67	84873.39
7	11.96	5.83	54.62	0.13	19.05	10.92	1.67	85523.94
8	13.02	0.52	66.38	0.19	20.20	10.76	1.68	85476.70
9	13.11	6.89	58.12	0.13	18.42	10.92	1.69	86013.29
10	13.43	7.18	54.52	0.14	18.73	10.70	1.69	87360.43
11	12.30	1.27	61.85	0.15	18.45	11.02	1.69	85730.19
12	13.71	5.13	55.40	0.14	18.03	10.94	1.67	86922.99
13	12.49	0.84	66.81	0.19	18.94	10.98	1.67	85664.85
14	13.79	4.07	57.86	0.11	17.95	10.87	1.67	87368.86
15	12.22	1.05	59.45	0.16	18.24	10.78	1.67	88184.03
16	12.22	1.35	57.97	0.15	17.72	11.34	1.67	83052.58
17	12.71	1.22	63.91	0.18	18.36	11.74	1.69	80073.10
18	11.66	2.82	70.84	0.20	17.73	12.44	1.71	74529.88
19	9.12	10.27	59.60	0.19	16.78	13.08	1.72	70413.69
20	9.20	3.79	62.66	0.19	17.22	12.50	1.71	75150.10
21	13.25	2.96	54.15	0.15	18.42	11.29	1.71	83353.01
22	13.24	2.61	56.14	0.12	18.25	10.61	1.70	89226.54
23	11.46	1.31	65.50	0.19	18.54	11.43	1.71	82780.22
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.56	3.62	61.15	0.16	18.21	11.36	1.69	82938.68
最 大 值	17.54	10.27	71.54	0.20	20.20	13.08	1.75	89226.54
發生時間	6	19	1	18	8	19		22
最 小 值	9.12	0.52	54.15	0.11	16.41	10.61	1.65	70413.69
發生時間	19	8	21	14	3	22		19
零點偏移(率)	-0.01 %	-0.09 %	-0.00 %	-0.08 %		-0.03	0.00	0.00 %
全幅偏移(率)	0.71 %	1.04 %	-0.16 %	0.16 %		-0.19	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 111年09月03日

報表日期: 111年09月03日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.22	4.69	59.55	1.29	17.50	11.35	2.00	70121.92
1	13.34	6.07	66.93	1.31	18.28	11.94	2.00	66089.64
2	9.47	4.33	56.68	1.28	17.07	10.94	2.02	73331.38
3	13.62	5.88	50.33	2.07	17.75	10.18	2.03	78866.24
4	14.00	4.88	53.74	1.51	17.62	10.54	2.03	80186.97
5	15.26	9.85	47.02	1.87	16.39	10.56	2.03	76771.70
6	7.80	3.67	55.22	1.43	17.45	11.06	2.03	70899.99
7	14.90	4.02	57.77	1.86	19.29	9.88	1.97	76260.94
8	13.82	6.55	47.80	1.34	18.64	10.03	1.97	80322.36
9	12.20	10.02	46.25	1.01	19.95	9.36	1.98	82054.63
10	12.71	1.16	53.71	1.24	17.11	10.25	1.98	76563.18
11	12.08	3.18	63.17	1.00	18.64	10.94	1.98	71703.09
12	11.14	2.64	67.33	1.28	19.17	11.30	1.96	70248.46
13	13.02	8.21	48.91	1.41	18.78	9.91	1.97	78439.52
14	13.14	6.97	45.20	1.36	17.59	10.19	1.98	75275.86
15	13.01	2.32	47.01	1.20	17.14	10.63	1.98	75350.92
16	12.38	4.70	45.63	1.06	17.49	10.96	1.98	72519.07
17	11.74	1.19	52.94	1.09	17.84	11.13	1.97	71693.55
18	7.01	2.38	64.25	1.15	16.84	12.50	1.98	63913.08
19	9.27	2.12	45.54	1.05	17.54	12.38	1.98	64022.57
20	14.00	6.68	47.14	1.24	18.34	10.89	1.97	75539.97
21	11.86	6.51	49.37	0.98	18.01	10.35	1.98	80582.86
22	9.52	5.28	58.49	0.92	18.45	11.14	1.98	73622.98
23	12.87	8.32	49.54	0.80	19.45	9.96	1.98	86233.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.10	5.07	53.31	1.28	18.01	10.77	1.99	74608.92
最 大 值	15.26	10.02	67.33	2.07	19.95	12.50	2.04	86233.28
發生時間	5	9	12	3	9	18		23
最 小 值	7.01	1.16	45.20	0.80	16.39	9.36	1.95	63913.08
發生時間	18	10	14	23	5	9		18
零點偏移(率)	-0.01 %	-0.11 %	0.00 %	-0.09 %		-0.07	0.00	0.00 %
全幅偏移(率)	1.17 %	0.97 %	-0.35 %	0.08 %		-0.01	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								