

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年05月09日

[illegible]

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年05月09日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.45	22.66	61.79	0.11	16.59	10.84	1.46	65194.55
1	14.50	4.77	46.09	0.22	16.23	10.76	1.46	66105.22
2	13.55	2.93	56.77	0.33	17.07	11.02	1.46	64063.19
3	14.60	9.71	63.39	0.40	17.57	10.70	1.46	66036.51
4	13.83	7.26	58.16	0.97	15.28	11.09	1.46	63541.45
5	15.13	4.95	58.86	0.85	15.30	10.95	1.46	66914.28
6	14.53	5.27	56.36	0.56	15.34	11.49	1.42	64534.57
7	13.48	3.22	67.68	0.32	15.69	11.61	1.41	60761.63
8	11.63	7.89	無效	0.17	14.85	13.05	1.43	50902.11
9	13.47	2.35	73.57	0.07	16.03	11.88	1.43	60148.09
10	14.37	2.71	63.85	0.08	17.76	10.93	1.45	65254.33
11	14.96	4.49	60.63	0.33	16.86	10.73	1.46	67649.39
12	14.95	2.99	55.61	0.27	17.29	10.69	1.47	67473.54
13	14.11	3.09	54.45	0.23	17.28	10.63	1.46	67844.85
14	13.26	4.96	52.33	0.28	16.15	11.35	1.46	64071.74
15	15.14	2.72	60.54	0.21	17.01	11.10	1.46	65158.82
16	14.06	4.80	58.84	0.48	15.31	11.65	1.46	62756.13
17	13.69	3.76	68.70	0.14	17.72	10.59	1.45	66337.24
18	13.62	2.77	56.12	0.25	16.92	10.74	1.43	66116.91
19	13.65	4.51	55.95	0.20	17.92	10.98	1.41	65282.27
20	13.23	6.61	62.64	0.14	17.21	11.14	1.41	64809.28
21	14.98	3.65	62.28	0.13	17.34	10.97	1.43	65148.56
22	14.70	5.02	47.86	0.42	17.16	10.46	1.43	67430.09
23	12.94	5.60	無效	0.30	16.11	12.12	1.43	57182.89
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	22	24	24	24	24	24
平 均 值	14.03	5.36	59.20	0.31	16.58	11.14	1.44	64196.57
最 大 值	15.14	22.66	73.57	0.97	17.92	13.05	1.49	67844.85
發生時間	15	0	9	4	19	8		13
最 小 值	11.63	2.35	46.09	0.07	14.85	10.46	1.41	50902.11
發生時間	8	9	1	9	8	22		8
零點偏移(率)	0.00 %	-0.01 %	-0.02 %	0.00 %		-0.09	0.00	0.00 %
全幅偏移(率)	-0.22 %	0.00 %	-0.20 %	0.58 %		-0.01	-0.06	0.00 %
有效比率	100.00 %	100.00 %	91.67%	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年05月09日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.07	2.13	65.31	2.85	16.80	9.65	1.38	78457.17
1	14.10	5.97	52.14	3.07	15.11	10.37	1.37	73315.89
2	14.33	13.56	47.17	2.47	17.22	10.16	1.37	73001.87
3	12.98	12.37	46.48	2.96	15.41	10.61	1.36	64244.42
4	15.01	5.97	65.65	3.83	16.92	9.21	1.36	72731.64
5	13.76	4.08	72.22	3.10	15.44	10.02	1.36	66945.15
6	14.11	9.92	60.80	2.87	16.02	9.68	1.37	69958.90
7	13.41	2.43	70.04	2.80	16.51	10.38	1.36	68609.17
8	13.73	9.45	74.48	2.61	16.56	10.55	1.36	63252.27
9	15.47	11.39	68.80	3.17	17.93	9.00	1.35	75580.03
10	13.94	11.81	68.41	2.53	17.43	9.41	1.35	73176.14
11	15.32	9.20	60.03	2.49	17.79	8.86	1.36	73376.33
12	13.55	3.45	66.94	2.54	16.28	9.58	1.37	76090.27
13	13.38	5.41	50.34	2.39	16.47	10.14	1.36	74380.62
14	14.72	3.15	56.91	2.36	17.06	10.50	1.34	69393.66
15	13.71	4.48	46.21	2.31	16.73	9.92	1.33	75822.20
16	15.40	3.64	61.81	2.37	16.23	10.48	1.33	71046.20
17	12.15	19.51	54.65	2.64	15.20	10.53	1.33	71991.92
18	13.88	2.32	55.69	2.45	17.66	10.10	1.33	71710.65
19	13.52	4.74	50.98	2.23	16.44	10.71	1.34	67695.14
20	14.26	6.16	51.84	2.30	16.66	10.40	1.35	72119.25
21	14.05	5.48	51.88	2.21	17.46	10.09	1.36	72891.09
22	14.59	3.05	54.29	2.41	17.42	10.03	1.35	74273.44
23	14.35	2.58	63.25	2.41	17.38	10.70	1.36	70275.70
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	14.07	6.76	59.01	2.64	16.67	10.04	1.35	71680.80
最 大 值	15.47	19.51	74.48	3.83	17.93	10.71	1.38	78457.17
發生時間	9	17	8	4	9	19		0
最 小 值	12.15	2.13	46.21	2.21	15.11	8.86	1.32	63252.27
發生時間	17	0	15	21	1	11		8
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	0.10 %	0.10 %	-0.53 %	0.66 %		0.06	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								