

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月01日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.21	3.86	59.88	0.32	21.21	11.26	1.34	77263.84
1	12.63	2.70	59.89	0.95	19.23	11.66	1.34	76981.40
2	6.32	4.34	66.74	0.56	19.73	11.62	1.35	77307.00
3	1.86	7.00	55.22	0.49	19.27	11.66	1.36	75869.99
4	1.55	3.57	56.49	0.21	21.12	10.95	1.37	79429.10
5	1.95	2.55	61.04	0.83	20.51	11.20	1.39	81429.97
6	0.19	3.21	55.06	0.84	20.22	11.53	1.41	75579.60
7	0.07	3.03	46.65	0.74	20.45	11.19	1.40	78069.19
8	0.13	3.86	52.45	0.92	19.24	11.46	1.39	76368.68
9	0.09	7.14	44.04	1.11	18.70	11.72	1.39	74874.80
10	6.05	5.86	47.07	1.35	17.99	11.98	1.40	74451.27
11	9.84	9.18	54.77	1.61	17.47	11.60	1.41	76507.25
12	8.21	8.80	57.72	1.50	17.69	11.81	1.39	73616.52
13	7.78	7.69	48.98	1.70	16.83	11.91	1.34	72823.15
14	9.84	5.73	57.07	1.80	17.65	11.68	1.34	73642.11
15	7.96	7.74	57.01	1.62	17.81	12.11	1.38	73213.43
16	4.00	3.50	63.74	1.37	18.10	12.17	1.39	72330.92
17	0.13	3.97	67.49	1.51	17.33	13.12	1.48	65184.31
18	0.09	1.66	56.76	1.24	18.47	12.28	1.44	71463.20
19	0.34	1.03	61.76	1.03	19.44	11.64	1.43	75918.34
20	1.23	1.47	60.46	1.12	19.36	11.62	1.41	75853.11
21	4.94	1.70	60.29	1.02	19.61	11.31	1.41	78202.34
22	6.95	1.71	66.26	1.31	19.14	11.92	1.41	73824.70
23	8.69	2.35	56.89	1.43	19.05	11.83	1.41	74774.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.21	4.32	57.24	1.11	18.98	11.72	1.39	75207.47
最 大 值	12.63	9.18	67.49	1.80	21.21	13.12	1.61	81429.97
發生時間	1	11	17	14	0	17		5
最 小 值	0.07	1.03	44.04	0.21	16.83	10.95	1.33	65184.31
發生時間	7	19	9	4	13	4		17
零點偏移(率)	-0.04 %	0.00 %	-0.04 %	-0.01 %		0.05	0.00	0.00 %
全幅偏移(率)	3.18 %	0.17 %	-0.57 %	-0.13 %		0.29	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月01日

項目 單位	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO ₂ _C	#2-H ₂ O	#2-O ₂ _C	#2-OPAC	#2-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.14	4.61	66.76	2.07	17.91	10.45	1.31	68065.04
1	17.38	4.66	58.22	2.87	16.52	10.65	1.32	68043.86
2	10.50	0.87	59.70	1.68	18.50	10.76	1.31	66075.95
3	10.82	3.73	68.79	1.64	19.40	10.09	1.30	69340.76
4	8.45	4.31	64.44	1.65	18.16	10.51	1.30	65486.16
5	9.75	1.16	65.48	1.05	20.18	10.08	1.30	68939.88
6	11.69	4.73	56.75	5.92	21.72	8.75	1.28	69449.66
7	8.36	1.96	51.02	1.94	17.03	10.77	1.27	64407.47
8	11.18	1.35	52.14	1.82	18.04	10.53	1.28	67648.90
9	11.68	3.54	60.27	2.34	16.80	10.41	1.28	66727.12
10	11.57	4.35	58.11	2.36	17.64	10.27	1.27	65940.55
11	10.23	1.22	66.20	2.38	16.48	10.67	1.25	62683.37
12	11.38	1.26	67.36	2.09	17.08	10.99	1.25	61211.54
13	10.45	1.51	69.97	2.30	16.64	11.15	1.27	62894.49
14	10.20	1.31	68.62	1.77	18.12	10.53	1.28	67113.98
15	9.14	3.88	68.45	2.26	16.45	11.27	1.29	64013.52
16	5.19	1.75	73.17	1.84	17.13	11.36	1.30	62817.26
17	5.43	0.78	72.26	1.48	18.31	10.85	1.29	65094.75
18	9.50	0.93	60.71	1.64	18.18	10.60	1.28	66742.39
19	11.04	6.80	62.82	2.40	15.92	11.45	1.28	63526.96
20	8.97	1.30	66.06	1.86	17.40	11.14	1.28	64361.10
21	12.85	7.11	72.30	2.32	16.31	11.32	1.30	62879.51
22	9.46	1.70	67.87	2.04	16.71	11.16	1.30	63661.73
23	9.55	2.28	67.53	1.98	17.15	11.59	1.32	61189.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.29	2.80	64.38	2.15	17.66	10.72	1.29	65346.49
最 大 值	17.38	7.11	73.17	5.92	21.72	11.59	1.33	69449.66
發生時間	1	21	16	6	6	23		6
最 小 值	5.19	0.78	51.02	1.05	15.92	8.75	1.25	61189.74
發生時間	16	17	7	5	19	6		23
零點偏移(率)	-0.02 %	0.00 %	-0.02 %	0.00 %		-0.03	0.00	0.00 %
全幅偏移(率)	-1.05 %	0.97 %	0.26 %	0.59 %		0.16	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月01日

項目 單位	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.84	4.96	65.15	2.49	18.76	9.41	1.34	91799.94
1	14.50	15.54	54.10	3.18	17.47	9.74	1.35	91216.93
2	13.22	5.03	52.81	2.96	16.24	10.65	1.35	83650.05
3	2.36	6.05	58.50	2.14	16.06	10.42	1.35	88297.76
4	13.27	2.29	64.14	2.74	17.32	10.29	1.33	85016.24
5	12.26	9.96	55.40	2.32	17.84	10.10	1.33	85868.50
6	10.27	3.44	53.99	2.66	18.95	8.82	1.32	91128.52
7	7.15	5.25	65.00	2.38	15.72	11.11	1.32	80312.63
8	8.64	1.19	56.09	1.98	16.70	10.42	1.33	84386.35
9	12.16	2.38	53.43	2.47	14.81	10.62	1.32	81370.43
10	16.56	4.51	57.01	3.53	14.28	10.54	1.32	83839.46
11	13.98	9.97	59.21	4.52	11.61	11.62	1.30	76575.31
12	10.06	2.34	60.95	2.98	14.11	11.49	1.33	83950.08
13	10.28	1.48	63.39	2.98	14.28	11.69	1.33	84342.42
14	8.04	3.00	58.69	2.51	15.08	10.97	1.33	84553.80
15	4.49	1.42	65.19	2.19	14.78	11.35	1.33	78161.02
16	3.96	1.78	65.19	2.12	16.18	11.10	1.34	79406.37
17	6.06	2.67	58.01	2.11	15.62	10.71	1.31	83367.21
18	4.20	1.81	66.77	2.20	15.36	11.17	1.31	80155.65
19	2.59	1.36	63.71	1.73	16.37	11.28	1.32	79613.92
20	3.34	1.66	59.44	1.74	17.15	10.45	1.33	85532.21
21	4.63	1.73	59.36	1.92	15.64	10.84	1.33	82316.68
22	4.93	1.41	58.51	1.97	16.20	10.75	1.33	81165.52
23	5.42	2.09	60.02	1.87	17.33	10.47	1.34	87048.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.63	3.89	59.75	2.49	15.99	10.67	1.33	83878.13
最 大 值	16.56	15.54	66.77	4.52	18.95	11.69	1.36	91799.94
發生時間	10	1	18	11	6	13		0
最 小 值	2.36	1.19	52.81	1.73	11.61	8.82	1.30	76575.31
發生時間	3	8	2	19	11	6		11
零點偏移(率)	-0.04 %	0.00 %	-0.20 %	-0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	1.65 %	0.09 %	-0.16 %	0.23 %		0.37	0.02	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								