

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 111年06月11日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	14.45	11.38	57.15	0.17	20.96	10.07	1.48	93206.25
1	13.74	2.11	57.25	0.18	19.62	10.39	1.49	92898.89
2	13.90	3.42	55.13	0.19	19.31	10.26	1.48	92572.45
3	14.78	12.90	57.98	0.15	18.78	10.49	1.48	90794.31
4	15.06	1.11	67.86	0.14	19.54	10.18	1.48	95791.44
5	15.32	4.08	59.22	0.24	19.28	10.23	1.46	93650.89
6	14.10	3.19	60.71	0.31	16.80	11.26	1.46	91501.33
7	13.63	2.80	55.82	0.11	18.78	10.59	1.48	90738.39
8	16.35	3.18	62.51	0.13	19.15	10.24	1.48	94532.92
9	13.49	3.99	58.05	0.13	19.77	10.39	1.45	92726.72
10	13.30	6.85	64.80	0.13	19.05	10.21	1.48	95628.94
11	13.61	2.96	59.89	0.17	17.07	10.77	1.46	93022.87
12	14.67	2.43	65.33	0.25	17.54	10.78	1.47	92655.57
13	14.93	8.59	60.48	0.48	16.81	10.85	1.47	91282.01
14	15.19	20.94	63.78	1.91	15.61	10.93	1.44	85860.81
15	14.83	1.22	60.17	0.42	16.93	10.72	1.41	88002.67
16	14.37	2.65	64.09	0.23	17.67	10.52	1.45	91990.82
17	15.12	11.35	54.42	0.22	18.56	10.20	1.43	90935.71
18	16.11	1.64	56.47	0.23	16.65	11.10	1.41	88282.98
19	12.54	2.49	59.99	0.11	16.93	11.67	1.42	84178.51
20	14.70	6.79	58.50	0.18	17.59	11.22	1.45	89022.55
21	11.64	6.58	50.18	0.14	17.78	11.13	1.45	87748.02
22	12.95	4.05	60.75	0.15	19.73	10.78	1.45	91262.33
23	14.27	10.48	56.20	0.15	19.68	10.54	1.44	92707.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	14.29	5.72	59.45	0.27	18.32	10.65	1.46	91291.44
最 大 值	16.35	20.94	67.86	1.91	20.96	11.67	1.49	95791.44
發生時間	8	14	4	14	0	19		4
最 小 值	11.64	1.11	50.18	0.11	15.61	10.07	1.39	84178.51
發生時間	21	4	21	7	14	0		19
零點偏移(率)	-0.02 %	0.00 %	-0.00 %	-0.02 %		-0.02	0.00	0.00 %
全幅偏移(率)	3.39 %	0.70 %	-0.13 %	0.20 %		-0.03	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

