

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 111年10月03日

[illegible]

報表日期: 111年10月03日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.80	7.23	47.93	0.16	18.57	11.33	1.45	81846.62
1	11.76	3.65	44.92	0.15	20.17	10.63	1.44	86358.89
2	9.76	2.97	46.69	0.13	18.02	11.11	1.43	84924.29
3	10.94	13.36	71.22	0.15	16.58	13.05	1.45	69386.73
4	11.89	0.96	39.82	0.14	18.55	10.87	1.43	86426.48
5	10.20	4.36	64.23	0.19	19.07	11.53	1.44	80548.42
6	18.20	5.80	41.99	0.14	19.21	10.47	1.42	94376.27
7	10.91	3.45	44.37	0.11	17.56	11.40	1.42	83076.76
8	11.33	1.73	47.81	0.14	18.19	11.24	1.43	83228.71
9	10.99	1.95	57.45	0.14	18.13	11.40	1.44	82539.81
10	11.20	4.42	49.69	0.15	19.05	10.71	1.44	87155.64
11	11.17	3.61	50.36	0.13	17.50	11.38	1.44	82526.25
12	10.58	5.66	51.40	0.12	16.94	11.55	1.45	81972.92
13	9.89	2.14	51.32	0.14	17.68	11.22	1.44	84653.94
14	7.40	3.76	61.53	0.17	17.43	12.24	1.43	76239.44
15	8.01	4.56	53.73	0.17	17.58	11.68	1.44	80754.66
16	11.70	5.02	47.45	0.15	18.01	11.34	1.44	82900.06
17	11.40	4.35	47.41	0.16	18.52	10.96	1.41	85958.63
18	9.81	4.56	56.27	0.15	17.98	11.64	1.41	80631.45
19	11.98	3.95	50.86	0.12	17.33	11.54	1.40	82958.74
20	10.45	3.66	48.22	0.11	17.66	11.10	1.41	85639.67
21	10.38	3.18	59.58	0.15	17.80	11.67	1.42	80357.26
22	10.46	3.17	63.91	0.16	17.05	11.91	1.43	79224.21
23	10.86	6.00	60.12	0.18	17.65	11.97	1.43	78963.27
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.92	4.31	52.43	0.15	18.01	11.41	1.43	82610.38
最 大 值	18.20	13.36	71.22	0.19	20.17	13.05	1.49	94376.27
發生時間	6	3	3	5	1	3		6
最 小 值	7.40	0.96	39.82	0.11	16.58	10.47	1.38	69386.73
發生時間	14	4	4	7	3	6		3
零點偏移(率)	-0.02 %	0.00 %	-0.04 %	-0.01 %		0.05	0.00	0.00 %
全幅偏移(率)	-1.12 %	-0.22 %	-0.08 %	0.18 %		0.07	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 111年10月03日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.95	5.91	41.42	0.29	17.54	10.77	1.19	73893.63
1	11.48	4.90	46.60	0.36	18.63	10.44	1.21	75648.88
2	11.25	6.94	47.36	0.65	16.79	10.49	1.21	75574.47
3	9.50	4.05	53.04	0.29	17.24	10.91	1.19	73640.51
4	10.30	5.34	47.76	0.36	17.59	10.52	1.18	76594.35
5	11.89	3.78	65.17	0.41	17.88	10.53	1.18	77851.36
6	13.02	6.07	49.38	0.49	17.74	10.73	1.19	76399.63
7	12.72	4.11	48.19	0.56	18.79	10.33	1.22	75012.44
8	9.27	2.10	42.90	0.33	17.32	10.42	1.24	80457.79
9	11.06	3.52	43.67	0.59	15.50	10.98	1.22	75286.20
10	10.57	3.36	50.05	0.26	17.36	10.40	1.25	77968.05
11	10.40	2.87	45.25	0.25	15.80	10.90	1.22	73432.63
12	11.69	1.51	47.37	0.39	15.76	10.96	1.25	72438.37
13	10.75	1.59	46.95	0.22	16.75	10.80	1.25	74043.92
14	9.77	2.39	51.65	0.23	16.05	11.41	1.25	68940.55
15	11.20	3.74	56.54	0.09	16.70	11.71	1.25	66553.23
16	7.36	1.46	61.35	0.06	17.66	11.44	1.24	69217.89
17	12.01	3.36	50.08	0.11	17.56	10.58	1.20	76163.98
18	9.99	4.61	45.73	0.08	16.24	10.99	1.25	72736.63
19	11.11	6.24	48.68	0.23	16.22	11.24	1.22	70267.90
20	10.97	5.00	51.88	0.37	16.06	11.22	1.18	70835.96
21	11.30	1.23	57.30	0.13	18.78	10.90	1.19	73146.51
22	10.43	5.13	57.99	0.12	18.00	11.50	1.19	69625.98
23	12.57	5.06	51.65	0.46	16.84	10.84	1.21	75649.48
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.86	3.93	50.33	0.31	17.12	10.88	1.22	73807.51
最 大 值	13.02	6.94	65.17	0.65	18.79	11.71	1.26	80457.79
發生時間	6	2	5	2	7	15		8
最 小 值	7.36	1.23	41.42	0.06	15.50	10.33	1.18	66553.23
發生時間	16	21	0	16	9	7		15
零點偏移(率)	-0.01 %	-0.00 %	-0.11 %	0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	-0.65 %	0.11 %	-0.04 %	0.08 %		0.38	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								