

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 111年09月11日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	8.81	4.11	48.03	0.16	21.68	11.80	1.49	62545.68
1	7.90	7.79	59.01	0.21	19.55	12.96	1.49	55756.44
2	7.99	13.88	53.25	0.21	17.74	14.04	1.50	48151.25
3	7.36	5.44	53.42	0.22	18.90	13.34	1.50	53742.83
4	10.32	3.02	63.75	0.21	20.17	12.29	1.49	60661.61
5	12.91	5.17	47.58	0.20	18.79	12.04	1.46	62591.44
6	13.42	1.64	41.15	0.27	18.94	11.95	1.46	61372.35
7	11.00	0.82	47.03	0.16	20.07	11.91	1.46	60635.85
8	13.19	2.21	43.77	0.15	21.09	11.42	1.46	64190.15
9	12.67	4.76	57.65	0.15	20.26	12.23	1.49	59141.39
10	11.16	6.84	60.82	0.16	19.25	12.61	1.49	57650.91
11	10.47	4.50	60.79	0.19	19.28	12.69	1.49	57123.19
12	11.81	5.18	61.71	0.18	19.31	12.64	1.49	57625.40
13	13.71	4.58	54.17	0.09	20.19	11.38	1.49	65916.29
14	12.48	4.80	43.19	0.12	18.96	12.02	1.49	61819.90
15	12.57	7.14	43.69	0.11	18.99	12.14	1.49	59533.57
16	11.12	7.30	54.08	0.18	19.53	12.69	1.50	55227.73
17	11.54	7.09	52.82	0.21	21.44	12.09	1.50	59307.60
18	12.87	2.73	47.58	0.20	21.75	11.38	1.49	64242.39
19	11.10	5.05	55.45	0.22	20.95	12.41	1.48	57949.32
20	12.70	4.16	46.66	0.21	21.20	11.93	1.46	61140.24
21	11.83	7.08	51.73	0.21	20.36	12.41	1.46	57700.37
22	9.75	6.78	60.74	0.22	19.99	12.86	1.48	54865.63
23	12.67	4.26	48.15	0.18	20.09	12.20	1.46	59074.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.31	5.26	52.34	0.18	19.94	12.31	1.48	59081.92
最 大 值	13.71	13.88	63.75	0.27	21.75	14.04	1.56	65916.29
發生時間	13	2	4	6	18	2		13
最 小 值	7.36	0.82	41.15	0.09	17.74	11.38	1.45	48151.25
發生時間	3	7	6	13	2	13		2
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	-0.01 %		0.00	0.00	0.00 %
全幅偏移(率)	0.27 %	-0.08 %	-0.69 %	0.09 %		-0.07	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 111年09月11日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.78	3.17	57.05	0.16	19.58	11.21	1.43	82946.42
1	10.48	0.64	57.78	0.15	18.16	11.50	1.43	81788.61
2	9.49	0.86	61.76	0.16	17.41	12.07	1.44	77556.05
3	9.86	3.20	42.81	0.16	18.35	12.01	1.45	77419.98
4	12.62	2.22	38.68	0.12	18.75	10.44	1.44	88964.52
5	13.46	1.08	46.28	0.09	17.04	11.20	1.43	84674.95
6	13.96	4.96	51.85	1.35	17.38	10.91	1.43	90325.06
7	12.12	0.72	51.23	0.18	16.92	11.47	1.43	82800.04
8	12.39	2.48	48.42	0.15	18.52	11.05	1.43	84783.73
9	11.45	4.46	44.46	0.18	18.55	11.35	1.41	82145.35
10	11.66	2.46	51.73	0.16	18.47	11.32	1.41	82746.31
11	10.49	1.55	55.44	0.18	19.12	11.21	1.40	82907.27
12	11.66	1.72	51.34	0.16	18.25	11.39	1.39	82916.03
13	12.66	3.49	46.58	0.15	17.89	11.32	1.41	82693.19
14	12.27	3.19	52.89	0.11	17.35	11.45	1.41	82658.57
15	12.36	3.43	56.41	0.17	19.79	10.74	1.41	86717.33
16	12.59	2.59	52.04	0.10	16.97	11.44	1.41	82703.16
17	12.87	2.42	55.32	0.16	18.57	11.55	1.42	80504.12
18	12.76	2.34	49.55	0.16	19.14	10.97	1.41	84892.37
19	12.43	2.61	51.50	0.16	18.63	11.29	1.43	82708.56
20	12.07	1.60	53.63	0.16	18.22	11.25	1.44	83427.50
21	12.08	2.31	55.06	0.18	18.78	11.42	1.43	81224.83
22	12.10	2.18	47.36	0.15	18.53	11.19	1.43	82848.48
23	12.12	7.46	55.68	0.20	19.96	11.01	1.43	83586.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.86	2.63	51.45	0.20	18.35	11.28	1.42	83164.13
最 大 值	13.96	7.46	61.76	1.35	19.96	12.07	1.50	90325.06
發生時間	6	23	2	6	23	2		6
最 小 值	8.78	0.64	38.68	0.09	16.92	10.44	1.37	77419.98
發生時間	0	1	4	5	7	4		3
零點偏移(率)	-0.34 %	0.00 %	-0.01 %	-0.01 %		0.01	0.00	0.00 %
全幅偏移(率)	0.02 %	0.05 %	0.02 %	0.15 %		0.11	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 111年09月11日

項目 單位	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO ₂ _C	#3-H ₂ O	#3-O ₂ _C	#3-OPAC	#3-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
0	9.37	2.81	54.28	0.19	19.09	10.67	1.42	74323.82
1	12.44	3.17	51.61	0.27	18.44	10.79	1.42	73110.30
2	10.81	4.04	44.42	0.27	17.61	10.99	1.41	70590.42
3	12.25	2.00	41.43	0.37	18.72	10.20	1.41	76953.76
4	12.86	8.96	44.64	0.53	16.91	10.70	1.38	75886.83
5	12.39	4.88	44.29	0.65	16.83	10.61	1.39	75258.86
6	13.00	1.05	46.29	0.84	16.35	10.91	1.38	72120.36
7	5.57	2.94	53.32	0.82	18.55	9.92	1.35	75023.81
8	9.64	3.81	52.90	0.81	17.24	10.43	1.36	75399.87
9	12.77	1.26	48.27	0.77	18.26	10.03	1.34	74275.31
10	11.53	0.88	48.77	0.32	17.59	11.13	1.34	68289.97
11	12.03	1.81	63.54	0.37	19.03	10.76	1.33	71548.17
12	13.56	2.56	55.67	0.63	19.04	9.82	1.34	78318.75
13	14.18	6.79	41.36	2.39	19.50	9.10	1.33	82622.74
14	12.58	2.51	40.41	1.14	17.04	9.83	1.34	77710.39
15	12.92	2.21	47.37	0.90	17.48	10.33	1.31	78775.87
16	12.36	5.05	47.82	0.56	17.44	10.94	1.32	72663.56
17	11.23	6.00	61.46	0.53	17.49	11.37	1.34	68782.68
18	13.62	1.44	60.98	0.97	18.85	9.94	1.31	76119.31
19	12.72	2.37	50.14	0.72	18.22	10.30	1.34	76420.95
20	11.86	2.05	57.82	0.66	18.68	9.98	1.34	76686.94
21	13.07	3.65	61.57	0.70	18.00	9.94	1.34	75598.71
22	12.40	1.74	70.46	0.69	17.77	10.44	1.33	72899.64
23	11.34	3.85	54.99	0.52	19.77	9.96	1.33	73731.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均値	11.94	3.24	51.83	0.69	18.08	10.38	1.35	74713.04
最大値	14.18	8.96	70.46	2.39	19.77	11.37	1.43	82622.74
發生時間	13	4	22	13	23	17		13
最小値	5.57	0.88	40.41	0.19	16.35	9.10	1.28	68289.97
發生時間	7	10	14	0	6	13		10
零點偏移(率)	-0.08 %	-0.00 %	-0.10 %	-0.02 %		-0.03	0.00	0.00 %
全幅偏移(率)	2.46 %	0.04 %	-0.21 %	0.15 %		0.26	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								