

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年04月26日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.31	5.70	63.20	0.96	18.64	12.11	1.49	62893.16
1	14.36	3.87	67.39	1.02	19.40	11.76	1.47	64245.89
2	15.49	5.03	49.04	1.50	18.38	11.28	1.43	67713.74
3	15.04	11.95	47.46	1.53	17.71	11.73	1.42	64822.24
4	14.74	14.14	46.29	1.67	17.40	11.86	1.41	64283.35
5	13.91	0.30	無效	0.03	17.46	12.25	1.38	61393.01
6	14.78	2.92	32.03	0.30	17.12	11.44	1.39	64775.81
7	15.94	2.94	32.27	0.31	18.56	11.36	1.38	61213.32
8	13.23	8.28	64.04	0.77	18.40	11.71	1.43	58798.04
9	13.66	18.32	50.26	1.12	17.44	11.68	1.46	61410.70
10	14.65	24.51	45.08	1.06	17.08	11.57	1.42	61873.57
11	14.82	19.77	43.81	1.07	17.00	11.70	1.42	60750.19
12	15.19	11.31	52.11	0.78	18.40	11.64	1.43	60725.30
13	15.42	18.11	50.81	0.97	18.87	11.18	1.41	62572.47
14	11.34	7.34	72.55	0.69	18.80	12.08	1.40	57247.53
15	14.69	27.32	50.67	0.73	18.67	11.43	1.41	61273.65
16	13.50	28.94	46.30	0.76	19.01	11.35	1.43	62154.08
17	13.84	13.78	46.71	0.81	18.10	11.53	1.44	61440.79
18	15.71	7.01	52.55	0.72	19.07	11.09	1.42	63401.11
19	13.47	12.76	61.96	0.68	18.96	11.75	1.41	59331.87
20	15.14	14.54	39.98	0.75	18.15	11.18	1.41	63154.63
21	13.66	5.81	65.45	0.57	18.63	11.83	1.41	58704.07
22	14.48	5.12	55.27	0.56	19.30	11.46	1.43	61157.34
23	14.54	6.16	71.49	0.59	18.55	12.14	1.45	57630.75
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	23	24	24	24	24	24
平 均 值	14.41	11.50	52.47	0.83	18.30	11.63	1.42	61790.28
最 大 值	15.94	28.94	72.55	1.67	19.40	12.25	1.49	67713.74
發生時間	7	16	14	4	1	5		2
最 小 值	11.34	0.30	32.03	0.03	17.00	11.09	1.35	57247.53
發生時間	14	5	6	5	11	18		14
零點偏移(率)	0.00 %	0.00 %	-0.17 %	0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	-0.10 %	-0.07 %	0.06 %	-0.18 %		0.06	-0.03	0.30 %
有效比率	100.00 %	100.00 %	95.83%	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 111年04月26日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	11.67	2.25	72.01	0.15	19.96	11.37	1.41	60229.97
1	14.81	1.70	51.23	0.14	20.87	10.54	1.40	65599.43
2	14.85	6.43	52.44	0.11	20.58	9.46	1.38	72472.41
3	14.46	3.82	53.30	0.21	19.19	9.96	1.38	69963.17
4	14.59	3.81	49.16	0.22	19.20	10.29	1.37	67753.16
5	14.83	2.36	53.49	0.22	19.40	10.28	1.36	68282.88
6	13.91	8.22	63.71	0.75	18.02	10.22	1.36	72404.63
7	14.61	1.46	67.26	0.18	18.45	10.35	1.39	68055.06
8	15.96	1.96	61.09	0.20	18.37	10.60	1.41	65594.21
9	13.54	8.32	68.45	0.67	15.59	11.39	1.37	65430.51
10	23.95	3.58	80.18	1.01	15.82	11.38	1.40	64747.43
11	7.60	36.29	70.34	0.79	16.88	10.92	1.41	65613.55
12	3.02	1.63	63.99	0.11	17.07	10.72	1.42	66596.51
13	1.06	5.21	63.98	0.15	15.81	11.81	1.41	59770.13
14	0.46	9.28	61.36	0.12	18.04	11.43	1.40	61638.09
15	1.20	7.39	68.94	0.11	17.51	12.07	1.41	57559.37
16	1.71	14.65	57.71	0.10	16.23	11.88	1.40	59585.99
17	13.38	11.15	52.77	0.18	17.11	10.95	1.39	65054.27
18	5.83	3.08	59.88	0.10	17.79	10.76	1.41	66969.98
19	2.99	7.51	58.96	0.11	17.15	11.06	1.41	65220.02
20	2.21	3.65	58.31	0.12	17.47	10.98	1.38	63591.11
21	7.61	4.76	58.97	0.08	16.98	11.37	1.38	61607.89
22	2.91	6.08	69.61	0.09	17.28	11.89	1.37	57949.44
23	1.76	10.25	57.19	0.10	17.53	11.43	1.36	61776.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.12	6.87	61.43	0.25	17.85	10.96	1.39	64727.75
最 大 值	23.95	36.29	80.18	1.01	20.87	12.07	1.43	72472.41
發生時間	10	11	10	10	1	15		2
最 小 值	0.46	1.46	49.16	0.08	15.59	9.46	1.32	57559.37
發生時間	14	7	4	21	9	2		15
零點偏移(率)	-0.21 %	0.00 %	-0.07 %	-0.04 %		-0.01	0.00	-0.20 %
全幅偏移(率)	1.77 %	1.80 %	-0.12 %	1.51 %		0.03	-0.03	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年04月26日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	12.98	8.98	55.29	2.53	19.03	10.03	1.46	69710.01
1	13.21	2.05	64.59	2.00	21.97	9.90	1.45	71578.35
2	14.86	1.81	70.67	3.03	18.43	9.84	1.47	69962.36
3	15.29	3.76	59.12	2.84	18.67	9.49	1.46	73762.96
4	14.56	7.56	52.56	3.05	18.72	9.24	1.46	76706.50
5	14.65	13.21	48.51	2.70	17.32	9.77	1.43	73391.95
6	14.50	4.92	56.56	2.87	17.17	10.06	1.47	72889.45
7	13.79	3.91	57.02	2.74	17.33	10.01	1.49	68901.48
8	14.62	4.41	58.48	2.57	17.79	9.81	1.48	69304.81
9	14.28	9.54	58.30	2.76	16.51	9.99	1.49	73736.08
10	14.03	16.21	61.39	2.81	15.57	10.24	1.49	73902.10
11	14.46	2.93	71.54	2.93	16.53	10.40	1.49	71534.03
12	14.85	2.38	67.48	3.12	18.23	9.73	1.46	75687.93
13	14.00	5.17	67.31	2.50	17.18	10.65	1.49	70304.22
14	13.47	14.11	59.19	2.37	20.10	9.54	1.50	76174.45
15	14.31	3.33	57.04	2.33	20.49	9.57	1.48	74661.60
16	15.19	17.91	51.31	2.28	18.01	9.63	1.46	71380.33
17	14.12	9.36	57.45	2.60	19.08	9.50	1.48	73224.29
18	13.66	22.22	56.81	2.92	16.98	9.77	1.47	70791.81
19	14.78	3.81	59.61	2.92	17.35	9.30	1.48	70047.75
20	14.35	7.79	58.56	3.03	17.50	9.24	1.49	72909.07
21	14.34	4.05	59.08	2.47	18.76	9.32	1.45	72591.50
22	14.82	14.24	42.28	2.63	18.97	8.90	1.43	72208.87
23	14.76	9.61	37.42	2.65	18.45	9.13	1.44	72487.56
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	14.33	8.05	57.82	2.69	18.17	9.71	1.47	72410.39
最 大 值	15.29	22.22	71.54	3.12	21.97	10.65	1.51	76706.50
發生時間	3	18	11	12	1	13		4
最 小 值	12.98	1.81	37.42	2.00	15.57	8.90	1.41	68901.48
發生時間	0	2	23	1	10	22		7
零點偏移(率)	-0.12 %	0.00 %	-0.07 %	-0.08 %		-0.04	0.00	0.00 %
全幅偏移(率)	-0.67 %	1.97 %	-1.22 %	0.61 %		0.04	0.02	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								