

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 111年04月20日

報表日期: 111年04月20日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.13	11.43	49.47	0.88	16.20	11.84	1.51	62528.87
1	13.21	6.53	61.22	0.39	18.60	11.29	1.52	65996.67
2	12.02	7.28	58.85	0.66	17.13	11.79	1.51	62488.75
3	11.36	16.11	70.76	0.61	16.78	12.37	1.50	59410.58
4	8.05	13.27	61.74	1.39	15.35	13.40	1.55	53881.25
5	13.69	6.17	48.82	0.42	18.49	11.11	1.47	65756.22
6	12.83	9.82	46.26	0.43	18.04	11.14	1.50	66672.57
7	12.08	35.02	40.18	1.13	15.79	11.94	1.51	61831.53
8	11.63	6.91	48.74	1.07	16.15	12.00	1.50	66082.28
9	12.30	14.46	44.77	1.78	15.62	11.98	1.47	66116.91
10	13.18	29.94	41.73	1.33	15.88	12.04	1.48	65416.12
11	10.99	32.73	40.51	0.57	17.37	11.60	1.50	64716.93
12	12.20	40.60	44.92	0.29	18.17	11.27	1.48	64246.35
13	12.36	7.44	51.79	0.29	18.62	11.10	1.53	64545.53
14	13.36	35.47	43.34	0.34	18.78	10.95	1.54	64378.83
15	11.78	14.27	51.42	0.31	18.91	10.81	1.53	65791.59
16	12.13	6.03	52.46	0.62	17.51	11.20	1.52	64571.95
17	13.71	7.07	58.15	1.07	16.24	11.49	1.54	62777.74
18	13.07	4.97	66.22	0.67	17.43	11.23	1.55	63835.32
19	12.73	18.12	43.19	0.90	15.77	11.93	1.52	59939.50
20	13.01	14.29	46.60	0.64	16.67	11.71	1.52	61294.60
21	11.39	7.66	49.84	0.76	16.14	12.13	1.51	58466.84
22	12.65	7.32	52.22	0.46	16.51	11.96	1.54	59902.91
23	12.93	7.04	57.54	0.30	17.07	11.90	1.55	60420.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.28	15.00	51.28	0.72	17.05	11.67	1.51	62961.28
最 大 值	13.71	40.60	70.76	1.78	18.91	13.40	1.78	66672.57
發生時間	17	12	3	9	15	4		6
最 小 值	8.05	4.97	40.18	0.29	15.35	10.81	1.46	53881.25
發生時間	4	18	7	12	4	15		4
零點偏移(率)	-0.01 %	-0.50 %	-0.12 %	0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	-3.99 %	-3.38 %	-0.84 %	-0.26 %		0.29	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 111年04月20日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	12.36	3.17	36.17	0.11	18.82	10.78	1.33	59857.49
1	11.31	3.47	40.04	0.14	20.58	10.60	1.33	60051.54
2	13.24	6.44	49.47	0.15	20.27	10.37	1.33	61618.53
3	11.35	11.44	24.50	0.11	18.87	10.40	1.33	61522.60
4	12.36	5.01	31.70	0.10	19.39	10.60	1.34	60236.10
5	11.39	5.17	29.73	0.09	18.52	11.05	1.33	57660.12
6	9.57	14.52	43.06	0.13	18.79	10.02	1.32	59205.67
7	11.19	16.68	43.79	0.15	16.79	10.99	1.33	55045.00
8	12.72	5.38	47.54	0.23	17.86	10.55	1.32	60640.63
9	12.34	4.32	50.42	0.15	18.72	10.45	1.33	61642.09
10	11.30	29.37	53.38	0.18	18.74	10.16	1.36	63047.31
11	12.41	38.35	46.16	0.25	17.66	10.39	1.35	60511.72
12	10.81	4.40	43.66	0.15	17.04	10.91	1.34	56844.58
13	12.26	35.86	55.63	0.20	18.10	10.46	1.38	61482.24
14	11.27	7.63	67.97	0.23	16.71	10.58	1.35	62294.67
15	12.53	3.17	52.80	0.19	17.02	10.68	1.33	59454.10
16	12.18	8.00	57.07	0.42	17.17	10.43	1.33	61769.42
17	12.80	2.07	69.65	0.41	17.63	10.59	1.33	60578.45
18	11.11	7.29	80.72	0.28	17.51	10.61	1.37	61430.76
19	11.90	2.64	66.67	0.26	15.97	10.88	1.38	58145.35
20	11.85	11.03	52.28	0.38	15.88	10.84	1.38	57195.91
21	11.02	12.70	58.38	0.17	16.74	10.75	1.38	56543.77
22	12.05	4.71	43.80	0.12	16.55	10.63	1.38	56189.85
23	11.74	23.12	46.98	0.30	15.74	10.75	1.38	54487.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.79	11.08	49.65	0.20	17.79	10.60	1.35	59477.32
最 大 值	13.24	38.35	80.72	0.42	20.58	11.05	1.38	63047.31
發生時間	2	11	18	16	1	5		10
最 小 值	9.57	2.07	24.50	0.09	15.74	10.02	1.31	54487.67
發生時間	6	17	3	5	23	6		23
零點偏移(率)	-0.43 %	-0.03 %	-0.14 %	-0.04 %		0.02	0.00	0.00 %
全幅偏移(率)	-0.43 %	-0.61 %	-1.31 %	-0.21 %		-0.08	-0.06	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 111年04月20日

報表日期: 111年04月20日

項目 單位	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
0	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
1	12.13	3.71	55.02	1.73	17.82	10.44	1.43	75680.39
2	12.06	2.78	55.90	1.93	18.54	10.21	1.42	78226.84
3	11.60	3.87	54.81	2.01	17.09	10.19	1.41	77768.76
4	11.95	3.50	52.76	1.95	18.07	10.22	1.42	77950.40
5	11.95	6.15	50.04	2.00	17.15	10.42	1.43	77670.45
6	11.65	5.04	65.00	1.98	16.86	11.47	1.42	69952.72
7	11.95	5.09	53.46	1.98	17.85	10.09	1.40	80140.95
8	11.57	2.68	53.43	2.13	16.73	10.10	1.41	64970.48
9	11.94	11.38	52.36	2.48	15.29	10.57	1.43	73422.27
10	12.06	5.67	56.41	2.28	16.29	10.53	1.45	75310.52
11	11.84	10.39	51.16	2.25	16.72	10.04	1.47	77643.18
12	12.19	3.50	52.92	2.26	16.56	10.24	1.44	74101.47
13	11.69	4.35	54.76	2.32	15.67	10.46	1.43	73513.68
14	12.00	11.50	56.15	2.54	15.09	10.66	1.43	71106.45
15	11.80	10.69	56.00	2.53	15.73	10.42	1.47	74603.57
16	11.59	30.57	47.70	2.33	17.37	9.52	1.48	73867.83
17	11.89	13.03	46.49	2.45	16.42	9.64	1.48	68799.18
18	11.87	13.88	51.83	2.18	16.75	9.49	1.47	73492.48
19	12.02	無效	37.08	4.63	18.27	8.85	1.44	67287.89
20	12.19	11.12	59.40	2.43	15.67	9.55	1.43	70778.97
21	12.40	16.09	49.93	2.08	16.88	9.62	1.43	74079.23
22	11.54	34.39	35.87	1.90	17.32	9.30	1.44	73209.42
23	11.31	7.03	35.93	1.89	15.77	9.87	1.43	69738.83
24	11.57	15.47	39.15	1.42	17.08	10.04	1.43	70216.87
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	23	24	24	24	24	24	24
平 均 值	11.87	10.08	50.98	2.24	16.79	10.08	1.44	73480.53
最 大 值	12.40	34.39	65.00	4.63	18.54	11.47	1.49	80140.95
發生時間	20	21	5	18	1	5		6
最 小 值	11.31	2.68	35.87	1.42	15.09	8.85	1.38	64970.48
發生時間	22	7	21	23	13	18		7
零點偏移(率)	0.00 %	-0.03 %	-0.03 %	-0.03 %		0.01	0.00	0.00 %
全幅偏移(率)	-1.81 %	-1.18 %	-0.92 %	-0.31 %		-0.03	0.00	0.20 %
有效比率	100.00 %	95.83%	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								