

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 111年11月06日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 111年11月06日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.11	4.45	55.21	0.22	17.04	10.90	1.43	64690.91
1	3.73	7.15	55.05	0.17	18.14	10.87	1.41	63971.99
2	2.72	2.72	55.70	0.11	19.92	10.46	1.40	65724.21
3	7.07	2.98	59.39	0.33	18.60	10.68	1.40	65693.35
4	5.02	3.08	52.61	0.23	17.57	10.86	1.41	65418.12
5	7.98	11.74	59.42	0.82	15.80	11.56	1.41	61558.44
6	5.05	4.98	55.09	0.19	18.49	10.38	1.38	58150.12
7	5.71	9.35	63.21	0.35	16.02	11.62	1.38	60903.91
8	8.90	7.16	61.70	0.30	17.10	11.30	1.39	62974.25
9	9.06	5.33	53.91	0.43	17.19	11.00	1.35	64437.55
10	11.15	16.09	70.55	0.52	17.19	11.04	1.37	64021.21
11	11.02	6.28	60.14	0.72	16.13	11.47	1.38	60966.90
12	10.46	3.10	61.71	0.64	16.27	11.18	1.38	63410.78
13	10.46	11.36	59.69	0.39	18.47	10.69	1.38	65367.34
14	11.21	11.20	62.35	0.69	15.84	11.19	1.40	64544.29
15	6.89	4.60	71.27	0.22	17.85	11.55	1.38	60791.42
16	7.90	9.68	54.36	0.32	18.87	10.47	1.36	66354.66
17	8.11	4.79	47.34	0.25	18.02	10.48	1.34	67346.62
18	11.50	10.79	51.54	1.41	17.23	10.49	1.36	67449.26
19	8.60	1.03	60.58	0.51	17.96	11.00	1.36	63551.58
20	10.25	4.10	49.93	0.77	18.40	10.57	1.36	65712.06
21	9.86	1.71	64.40	0.45	17.47	11.00	1.34	63655.53
22	9.36	2.30	63.02	0.38	17.94	10.81	1.33	64454.54
23	8.74	1.78	52.57	0.31	18.92	10.31	1.33	67059.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.12	6.16	58.36	0.45	17.60	10.91	1.37	64092.00
最 大 值	11.50	16.09	71.27	1.41	19.92	11.62	1.43	67449.26
發生時間	18	10	15	18	2	7		18
最 小 值	2.72	1.03	47.34	0.11	15.80	10.31	1.33	58150.12
發生時間	2	19	17	2	5	23		6
零點偏移(率)	0.00 %	0.00 %	-0.07 %	-0.01 %		0.00	0.00	0.00 %
全幅偏移(率)	1.98 %	1.18 %	-0.25 %	0.30 %		0.09	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

