

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年07月29日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.25	6.31	56.51	0.09	19.39	12.24	1.59	75806.56
1	12.81	10.13	55.52	0.10	20.46	11.75	1.61	79017.31
2	15.08	5.21	51.87	0.39	18.67	11.61	1.61	82374.65
3	13.48	5.55	54.34	0.28	18.24	11.81	1.61	81185.24
4	14.95	7.55	48.49	0.45	18.93	11.43	1.61	82849.50
5	15.17	6.03	49.95	0.09	20.35	11.21	1.57	84490.62
6	14.21	5.34	51.63	0.09	19.50	11.27	1.55	84260.51
7	13.53	10.12	69.26	0.06	17.92	12.57	1.59	73873.37
8	13.05	6.28	57.90	0.18	18.75	11.78	1.59	80663.44
9	14.40	2.73	46.79	0.22	19.40	11.14	1.58	84928.77
10	14.07	3.87	42.11	0.15	19.14	11.06	1.58	86182.95
11	15.41	6.56	38.67	0.34	18.80	11.01	1.57	87071.92
12	13.66	7.12	41.55	0.42	18.76	11.19	1.58	85109.91
13	13.28	3.93	54.52	0.10	20.40	10.96	1.59	85105.53
14	14.29	6.56	47.27	0.10	20.38	10.67	1.58	88094.81
15	13.11	11.56	39.77	0.13	19.31	11.07	1.57	85683.17
16	9.92	8.08	46.37	0.13	19.38	11.02	1.57	86249.40
17	11.18	15.62	42.00	0.37	16.55	11.56	1.57	81083.83
18	15.99	3.01	38.65	0.33	17.80	11.15	1.57	82534.72
19	16.62	1.37	42.39	0.23	19.17	10.93	1.58	85136.32
20	11.96	13.16	38.85	0.55	17.12	11.22	1.57	84010.53
21	13.26	5.10	39.71	0.39	18.26	11.12	1.56	83059.46
22	13.89	7.11	49.74	0.20	18.12	11.84	1.55	77367.68
23	11.93	6.27	58.12	0.12	19.01	11.99	1.56	77797.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	13.60	6.86	48.42	0.23	18.91	11.40	1.58	82664.07
最 大 值	16.62	15.62	69.26	0.55	20.46	12.57	1.65	88094.81
發生時間	19	17	7	20	1	7		14
最 小 值	9.92	1.37	38.65	0.06	16.55	10.67	1.52	73873.

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 111年07月29日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.02	1.31	57.54	0.16	18.85	11.09	1.43	60668.09
1	14.93	1.98	53.70	0.40	20.34	10.43	1.44	63680.70
2	13.56	8.30	48.85	0.97	16.27	11.06	1.43	61411.89
3	15.07	4.50	52.42	0.80	16.46	11.43	1.44	58514.34
4	13.21	6.78	52.90	0.43	17.18	11.16	1.45	60847.36
5	12.16	3.40	52.33	0.27	16.77	11.61	1.44	57693.32
6	12.86	1.49	50.65	0.23	18.34	10.85	1.46	56243.81
7	14.64	5.67	52.14	0.37	17.44	11.31	1.47	58803.67
8	14.58	3.42	48.85	0.20	17.96	11.03	1.49	60703.81
9	15.14	5.24	50.98	0.16	18.00	10.75	1.48	63794.82
10	14.91	2.32	63.42	0.25	17.23	10.92	1.49	63383.87
11	14.07	1.59	59.95	0.18	17.03	11.12	1.51	62204.75
12	13.35	0.90	56.78	0.13	18.72	10.75	1.50	63049.25
13	14.52	4.09	55.79	0.28	17.46	10.99	1.50	61816.01
14	10.57	3.28	50.53	0.23	19.17	10.92	1.50	61231.38
15	14.20	1.94	61.98	0.11	17.34	10.82	1.51	63995.63
16	15.05	3.25	60.15	0.21	16.22	11.20	1.50	60433.47
17	16.76	5.82	48.12	0.46	14.99	11.26	1.47	58252.51
18	14.57	2.70	44.14	0.26	16.30	10.97	1.46	60313.00
19	14.90	1.90	48.69	0.17	17.29	10.67	1.47	61050.47
20	13.72	5.65	50.25	0.16	16.98	10.67	1.46	60774.37
21	13.71	2.56	58.98	0.17	17.59	10.77	1.47	62207.09
22	12.37	0.90	58.40	0.16	18.04	11.38	1.46	58418.86
23	11.32	0.87	70.90	0.20	19.34	11.28	1.45	57156.56
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	13.88	3.33	54.52	0.29	17.55	11.02	1.47	60693.71
最 大 值	16.76	8.30	70.90	0.97	20.34	11.61	1.51	63995.63
發生時間	17	2	23	2	1	5		15
最 小 值	10.57	0.87	44.14	0.11	14.99	10.43	1.42	56243.81
發生時間</								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 111年07月29日

報表日期: 111年07月29日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.52	3.98	53.69	1.07	18.52	9.98	1.45	72003.47
1	13.57	6.90	48.46	1.23	19.03	9.89	1.48	73097.11
2	13.84	2.65	49.73	1.30	17.69	10.14	1.48	72184.58
3	14.83	4.64	48.00	1.63	15.89	10.19	1.49	70567.74
4	13.43	4.28	51.83	1.63	17.25	9.89	1.49	75118.25
5	11.51	7.25	62.17	1.18	18.46	10.59	1.49	69469.69
6	14.66	2.80	63.27	1.58	16.53	10.49	1.50	76737.37
7	12.39	7.64	46.16	1.04	18.65	9.78	1.46	73769.50
8	13.46	1.03	51.14	1.25	18.35	9.97	1.49	73105.46
9	10.99	3.53	48.77	1.28	17.04	9.88	1.45	72081.84
10	10.51	2.37	47.71	1.33	16.53	9.96	1.50	73141.06
11	12.96	2.72	50.95	1.34	16.05	10.44	1.49	71445.23
12	10.13	2.41	51.94	1.17	16.18	10.53	1.44	70454.41
13	0.93	8.67	55.47	0.53	18.27	9.99	1.43	69253.28
14	11.66	1.95	52.00	1.09	17.06	9.87	1.45	73674.17
15	10.64	4.40	49.64	0.79	16.82	10.53	1.49	70129.60
16	13.51	11.20	54.91	1.33	17.07	9.93	1.50	72793.14
17	15.23	5.26	54.42	2.10	14.81	10.65	1.49	67240.55
18	10.25	4.85	68.50	2.04	15.29	10.40	1.46	71207.62
19	15.84	1.75	53.76	1.63	16.04	10.25	1.46	69423.25
20	15.33	2.05	57.11	1.24	17.26	10.08	1.49	71734.67
21	14.36	9.38	54.37	1.64	15.35	10.02	1.49	73101.00
22	11.38	1.95	73.70	1.38	16.29	10.94	1.45	71491.36
23	13.26	2.20	70.41	1.66	15.33	11.84	1.45	59852.62
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.34	4.41	54.92	1.35	16.91	10.26	1.47	71378.21
最 大 值	15.84	11.20	73.70	2.10	19.03	11.84	1.51	76737.37
發生時間	19	16	22	17	1	23		6
最 小 值	0.93	1.03	46.16	0.53	14.81	9.78	1.43	59852.62