

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 111年11月29日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.18	2.76	51.59	0.16	21.56	11.04	1.36	76105.31
1	0.13	3.70	56.36	0.33	21.76	10.98	1.38	76443.72
2	1.65	7.86	50.86	0.21	23.24	10.52	1.40	78694.39
3	2.64	1.35	68.27	0.51	21.06	11.51	1.41	72884.48
4	1.58	1.15	64.82	0.51	20.91	11.57	1.41	72595.30
5	0.86	4.46	66.68	0.82	20.68	11.69	1.41	72055.03
6	0.14	4.76	67.01	0.97	19.91	12.03	1.41	70239.59
7	0.09	2.99	65.75	0.50	20.87	11.56	1.41	72748.11
8	0.12	5.28	47.14	0.85	20.10	11.49	1.37	73697.61
9	2.36	4.38	54.79	0.95	20.10	11.38	1.37	74754.37
10	7.88	5.48	56.46	1.13	19.67	11.63	1.40	73253.91
11	10.02	2.77	53.14	1.38	18.53	11.89	1.38	72899.37
12	0.47	2.13	54.81	1.00	19.35	11.85	1.40	74669.01
13	8.57	2.88	61.59	1.87	19.44	11.85	1.41	72324.99
14	11.31	9.80	58.20	1.64	17.93	13.06	1.44	63815.06
15	0.81	9.01	62.74	1.59	17.91	13.41	1.43	61610.14
16	7.24	1.52	54.34	0.98	20.34	11.61	1.41	74239.25
17	19.23	1.68	70.17	1.59	20.20	12.25	1.39	70907.54
18	1.44	2.39	56.26	0.82	20.19	12.04	1.40	70384.32
19	2.44	1.71	55.95	0.90	19.81	11.29	1.42	75620.66
20	7.55	4.71	49.65	1.31	18.67	11.45	1.42	74762.32
21	9.26	3.36	65.16	1.24	19.30	11.82	1.41	71143.59
22	2.34	3.15	54.09	0.32	21.14	11.36	1.41	74216.80
23	0.08	4.08	58.28	0.63	20.65	11.67	1.39	72836.45
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.10	3.89	58.50	0.93	20.14	11.71	1.40	72620.89
最 大 值	19.23	9.80	70.17	1.87	23.24	13.41	1.68	78694.39
發生時間	17	14	17	13	2	15		2
最 小 值	0.08	1.15	47.14	0.16	17.91	10.52	1.33	61610.14
發生時間	23	4	8	0	15	2		15
零點偏移(率)	-0.02 %	-0.07 %	-0.01 %	-0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	1.05 %	0.69 %	-0.65 %	0.26 %		0.22	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

