

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 111年03月31日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	7.43	10.76	100.99	0.72	16.91	12.75	1.53	72941.57
1	12.00	4.09	85.17	0.49	19.33	11.27	1.54	83743.20
2	15.31	2.66	70.98	1.02	18.19	11.24	1.53	85755.26
3	14.78	4.43	61.10	1.52	16.39	11.63	1.51	83469.66
4	14.88	8.48	58.51	1.72	16.02	11.87	1.51	81653.77
5	13.97	7.38	52.89	1.47	16.89	11.49	1.54	92798.60
6	15.77	8.06	55.10	1.99	16.20	11.70	1.55	82934.47
7	13.78	5.81	57.71	1.74	15.94	11.93	1.55	81127.07
8	14.58	6.06	55.05	1.85	15.73	11.91	1.53	81019.97
9	14.93	6.45	62.55	1.65	16.10	11.93	1.51	80313.95
10	14.74	5.70	64.16	1.70	15.89	11.99	1.52	80208.75
11	15.94	5.31	73.83	1.63	15.55	11.82	1.51	81648.47
12	14.27	5.49	61.91	2.28	14.66	11.94	1.51	81500.06
13	15.88	7.76	57.27	2.24	15.03	12.19	1.51	79773.53
14	14.86	14.54	54.38	1.56	15.68	12.19	1.56	79234.67
15	13.81	27.49	50.13	1.62	15.48	12.08	1.56	79900.25
16	15.51	19.24	52.18	2.03	15.08	12.11	1.53	80629.95
17	14.80	21.51	60.87	1.95	15.32	12.50	1.53	76947.11
18	14.95	6.46	67.88	1.10	16.63	12.17	1.50	79182.19
19	11.58	15.33	64.74	0.80	17.15	12.06	1.47	80042.52
20	15.03	44.26	54.02	1.50	16.28	11.90	1.50	81899.70
21	16.09	26.76	54.74	2.56	14.68	12.20	1.51	79832.62
22	13.39	5.18	71.65	1.17	16.72	11.54	1.51	84448.64
23	15.23	3.82	67.28	1.60	15.15	12.14	1.49	80690.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	14.31	11.38	63.13	1.58	16.12	11.94	1.52	81320.68
最 大 值	16.09	44.26	100.99	2.56	19.33	12.75	1.59	92798.60
發生時間	21	20	0	21	1	0		5
最 小 值	7.43	2.66	50.13	0.49	14.66	11.24	1.46	72941.57
發生時間	0	2	15	1	12	2		0
零點偏移(率)							0.00	
全幅偏移(率)							0.02	
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 111年03月31日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	15.32	1.94	65.25	0.14	18.69	12.12	1.46	57449.24
1	15.46	1.79	53.45	0.28	21.13	11.14	1.50	62595.43
2	17.17	24.34	53.76	1.66	18.18	11.60	1.50	61550.03
3	20.82	2.81	57.77	2.29	17.70	11.72	1.49	61453.19
4	15.26	2.08	55.94	1.60	18.07	11.80	1.49	60643.73
5	15.16	1.72	62.62	1.40	18.41	11.71	1.50	62000.09
6	15.99	1.64	66.82	1.61	17.31	12.10	1.47	59483.47
7	16.95	2.11	64.36	2.13	17.29	11.91	1.46	60671.93
8	14.58	22.70	61.65	1.48	16.59	12.22	1.45	58799.92
9	14.51	9.04	67.50	0.49	17.93	12.03	1.42	59389.88
10	14.01	4.25	58.52	0.18	17.22	12.06	1.45	61496.88
11	20.93	6.81	65.20	0.27	17.93	12.17	1.45	59983.52
12	14.13	7.07	71.82	0.12	17.88	12.30	1.45	59593.80
13	16.33	4.03	67.30	1.18	17.97	11.86	1.41	62709.68
14	19.74	17.45	63.91	1.74	16.70	12.15	1.45	60907.00
15	15.78	14.53	67.15	1.08	15.60	12.23	1.46	60402.23
16	14.37	3.24	73.62	0.24	16.23	11.37	1.50	61219.08
17	14.38	2.26	70.57	0.11	18.12	11.35	1.51	58879.38
18	12.66	6.59	67.71	0.14	16.12	12.05	1.51	55855.51
19	14.10	6.22	63.13	0.11	16.93	11.27	1.47	59380.08
20	16.18	5.86	64.54	0.39	15.84	11.42	1.46	59388.67
21	15.37	8.32	63.60	0.61	15.08	11.58	1.46	58311.19
22	15.33	7.65	62.09	0.63	15.38	11.51	1.49	57893.60
23	14.95	9.99	64.89	0.33	16.12	11.53	1.51	57577.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	15.81	7.27	63.88	0.84	17.27	11.80	1.47	59901.46
最 大 值	20.93	24.34	73.62	2.29	21.13	12.30	1.51	62709.68
發生時間	11	2	16	3	1	12		13
最 小 值	12.66	1.64	53.45	0.11	15.08	11.14	1.39	55855.51
發生時間	18	6	1	17	21	1		18
零點偏移(率)							0.00	
全幅偏移(率)							0.00	
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 111年03月31日

[illegible]