

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 111年09月08日

報表日期: 111年09月08日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.76	2.72	50.16	0.10	18.78	11.36	1.50	64935.96
1	11.31	2.75	47.21	0.14	19.69	11.41	1.51	64573.21
2	7.13	6.63	55.45	0.11	16.78	12.82	1.51	55708.59
3	9.20	4.93	59.76	0.12	18.02	12.08	1.48	61396.33
4	9.81	3.53	49.04	0.12	17.60	12.08	1.46	61935.03
5	10.44	4.38	57.06	0.56	17.22	12.26	1.48	67747.01
6	12.31	3.30	59.38	0.16	18.05	11.84	1.50	63856.63
7	13.33	3.48	56.16	0.10	17.34	11.87	1.51	63646.63
8	12.77	1.58	56.04	0.07	16.71	11.90	1.50	62329.86
9	11.17	1.58	60.99	0.13	17.67	11.95	1.50	61169.99
10	12.03	2.00	58.93	0.13	17.70	11.89	1.51	59753.99
11	13.06	3.63	65.62	0.13	17.56	11.89	1.46	60858.35
12	13.14	1.51	55.28	0.09	16.78	11.75	1.48	63748.94
13	12.25	4.77	45.27	0.09	16.31	12.35	1.49	58870.38
14	11.66	2.42	49.98	0.15	17.82	11.97	1.48	60190.98
15	12.54	1.58	49.62	0.10	17.53	12.05	1.46	60161.38
16	9.48	2.99	49.73	0.11	16.42	12.31	1.46	58084.70
17	6.93	4.01	57.56	0.15	16.79	12.62	1.47	56493.56
18	11.49	3.45	59.39	0.12	17.16	12.26	1.49	58842.09
19	11.81	5.26	51.67	0.11	16.89	12.42	1.49	57525.23
20	7.44	7.75	53.37	0.12	16.62	12.93	1.49	54558.26
21	10.51	4.96	47.14	0.15	18.63	11.83	1.46	61200.21
22	11.59	3.75	46.10	0.11	17.28	12.09	1.46	59851.90
23	12.88	9.04	40.46	0.14	16.84	11.94	1.46	60710.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.17	3.83	53.39	0.14	17.42	12.08	1.48	60756.22
最 大 值	13.76	9.04	65.62	0.56	19.69	12.93	1.55	67747.01
發生時間	0	23	11	5	1	20		5
最 小 值	6.93	1.51	40.46	0.07	16.31	11.36	1.45	54558.26
發生時間	17	12	23	8	13	0		20
零點偏移(率)	-0.02 %	0.00 %	-0.18 %	0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	0.01 %	0.10 %	-0.12 %	0.20 %		0.15	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 111年09月08日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.84	3.86	51.78	0.99	15.44	11.45	1.54	72180.47
1	12.33	2.86	54.44	0.49	17.82	11.12	1.54	73756.47
2	11.62	11.00	46.13	1.02	15.27	11.15	1.51	72352.43
3	12.14	4.28	49.17	0.86	14.90	11.67	1.51	70134.19
4	16.08	6.63	52.39	1.14	15.42	11.34	1.53	73299.68
5	10.26	1.38	57.63	0.59	15.81	11.23	1.54	74761.44
6	11.70	1.42	57.07	0.87	15.29	11.25	1.54	71957.35
7	10.89	1.71	65.28	0.92	15.42	10.82	1.49	82873.88
8	12.36	6.98	39.73	0.92	15.05	10.98	1.47	75653.48
9	12.33	6.47	44.00	0.37	15.58	11.12	1.48	74441.63
10	15.28	3.95	40.96	0.40	16.06	10.68	1.48	71834.44
11	9.25	4.11	56.64	1.79	13.33	11.74	1.47	65845.49
12	5.78	1.34	57.38	1.11	14.94	11.17	1.45	72368.22
13	13.84	1.64	54.59	1.51	14.94	11.29	1.47	69814.53
14	13.22	2.13	50.13	1.46	14.86	11.03	1.47	71211.73
15	11.45	1.90	54.74	1.11	15.05	11.41	1.44	70897.64
16	13.11	2.31	56.22	0.92	15.67	11.07	1.44	74151.62
17	12.72	1.44	57.93	1.62	13.85	11.37	1.44	70028.60
18	12.65	2.54	58.72	1.04	15.59	11.06	1.47	72773.75
19	13.17	2.57	54.30	0.77	16.12	10.73	1.43	74392.73
20	12.69	6.65	49.93	1.45	14.43	11.16	1.43	70650.34
21	12.46	5.61	53.92	0.98	15.31	11.35	1.44	70235.30
22	12.87	3.94	52.61	1.04	15.09	11.14	1.47	71995.76
23	12.69	5.97	57.68	1.10	15.42	11.29	1.46	71056.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.24	3.86	53.06	1.02	15.28	11.19	1.48	72444.50
最 大 值	16.08	11.00	65.28	1.79	17.82	11.74	1.55	82873.88
發生時間	4	2	7	11	1	11		7
最 小 值	5.78	1.34	39.73	0.37	13.33	10.68	1.43	65845.49
發生時間	12	12	8	9	11	10		11
零點偏移(率)	-0.02 %	-0.05 %	-0.03 %	-0.03 %		-0.03	0.00	0.00 %
全幅偏移(率)	0.70 %	0.44 %	-0.59 %	0.06 %		0.34	0.02	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								