

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 111年11月03日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.49	4.32	47.33	0.22	20.14	10.51	1.46	77823.75
1	5.99	1.54	55.88	0.18	20.09	11.33	1.46	73076.96
2	2.65	1.36	61.47	0.07	20.03	11.43	1.45	70618.74
3	2.34	1.49	70.62	0.07	20.46	10.68	1.45	79409.69
4	3.61	4.22	54.62	0.09	20.70	11.12	1.46	77480.09
5	4.36	3.94	42.74	0.14	20.60	10.99	1.42	76244.21
6	9.28	9.37	37.27	0.20	19.36	11.63	1.41	74212.03
7	6.70	2.28	46.81	0.18	19.60	11.73	1.41	73183.75
8	6.77	1.67	40.07	0.19	19.85	11.22	1.45	76627.52
9	5.94	1.51	44.06	0.15	19.42	11.02	1.46	78326.95
10	8.58	6.04	41.90	0.33	18.57	11.12	1.46	77260.27
11	5.95	5.51	39.08	0.17	19.26	10.89	1.42	76004.61
12	3.46	4.56	42.36	0.13	18.75	11.20	1.39	71819.20
13	1.61	6.98	42.98	0.23	18.11	11.47	1.41	70650.88
14	2.40	5.16	46.16	0.10	19.22	10.86	1.41	73716.75
15	8.41	8.58	46.14	0.33	18.65	11.43	1.41	58481.21
16	5.17	4.56	40.03	0.12	19.52	10.95	1.42	62865.55
17	3.71	4.04	42.70	0.07	19.89	11.15	1.46	62228.66
18	4.42	2.78	52.69	0.07	20.27	10.96	1.46	64413.67
19	4.20	5.19	48.64	0.12	19.31	11.18	1.46	63341.85
20	3.51	3.91	57.24	0.08	20.23	11.30	1.46	62088.36
21	10.06	4.73	49.81	0.34	20.07	10.98	1.46	64014.78
22	4.52	3.84	49.17	0.12	19.75	11.20	1.46	62957.82
23	1.59	6.99	57.56	0.13	18.69	12.20	1.47	57250.45
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.11	4.36	48.22	0.16	19.61	11.19	1.44	70170.74
最 大 值	10.06	9.37	70.62	0.34	20.70	12.20	1.50	79409.69
發生時間	21	6	3	21	4	23		3
最 小 值	1.59	1.36	37.27	0.07	18.11	10.51	1.38	57250.45
發生時間	23	2	6	2	13	0		23
零點偏移(率)	-0.02 %	-0.01 %	-0.00 %	-0.00 %		0.04	0.00	0.00 %
全幅偏移(率)	-0.83 %	0.24 %	-0.59 %	0.34 %		0.09	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 111年11月03日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.38	1.35	52.56	0.72	17.26	10.76	1.33	87469.11
1	10.58	2.39	54.76	0.23	19.47	10.65	1.33	87123.29
2	10.13	2.21	62.13	0.43	18.26	10.64	1.34	88412.26
3	10.19	1.95	65.42	0.34	19.11	10.46	1.35	89581.47
4	10.55	4.07	57.57	0.27	18.26	10.86	1.36	87036.43
5	6.71	9.11	67.36	0.14	17.59	11.68	1.36	80398.60
6	10.34	4.50	54.59	0.29	18.51	10.64	1.38	98021.50
7	9.54	3.87	61.09	0.13	19.19	10.15	1.38	92504.69
8	10.48	0.84	54.91	0.36	16.95	10.90	1.41	86729.79
9	11.08	6.14	57.74	0.68	15.18	11.30	1.41	85304.92
10	9.11	7.01	56.43	0.51	15.41	11.62	1.37	81985.81
11	6.04	5.96	61.08	0.22	15.69	11.46	1.35	81362.18
12	2.25	5.32	55.71	0.17	15.80	11.62	1.35	80049.18
13	2.36	10.47	65.63	0.24	15.30	11.93	1.36	80222.80
14	2.71	5.91	65.86	0.12	15.90	12.00	1.38	81198.53
15	3.90	3.72	60.13	0.12	16.35	11.40	1.39	62394.51
16	5.75	3.69	52.23	0.14	16.32	11.33	1.37	60515.81
17	5.97	4.59	60.22	0.19	16.27	11.29	1.36	62731.50
18	6.79	3.29	61.57	0.11	16.85	11.35	1.38	63076.31
19	6.61	11.62	58.08	0.23	15.53	11.55	1.38	61831.23
20	8.14	6.48	59.23	0.22	16.73	11.13	1.37	64087.54
21	7.42	7.37	60.02	0.22	16.24	11.37	1.37	62597.67
22	4.26	3.43	63.35	0.15	17.55	11.61	1.38	61002.05
23	4.67	3.75	58.70	0.14	18.22	10.88	1.38	64400.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.33	4.96	59.43	0.27	17.00	11.19	1.37	77084.90
最 大 值	11.08	11.62	67.36	0.72	19.47	12.00	1.43	98021.50
發生時間	9	19	5	0	1	14		6
最 小 值	2.25	0.84	52.23	0.11	15.18	10.15	1.33	60515.81
發生時間	12	8	16	18	9	7		16
零點偏移(率)	-0.05 %	0.00 %	-0.01 %	-0.01 %		-0.08	0.00	0.00 %
全幅偏移(率)	0.03 %	-0.07 %	-0.11 %	0.03 %		-0.13	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 111年11月03日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.04	1.88	46.21	2.12	17.62	9.68	1.34	80245.70
1	6.91	2.75	42.86	1.97	17.54	10.43	1.35	76293.75
2	7.76	4.48	40.74	2.02	18.60	9.99	1.35	77585.62
3	7.63	1.26	43.98	1.97	16.68	10.44	1.34	75463.18
4	5.89	2.42	40.16	1.64	16.77	10.64	1.33	74053.38
5	5.28	0.78	58.12	1.58	17.69	10.76	1.33	73529.02
6	8.09	3.32	48.68	1.97	16.78	10.42	1.33	78626.22
7	9.61	4.43	46.90	2.66	14.84	10.94	1.33	81414.30
8	9.69	1.82	51.95	2.67	15.94	10.50	1.35	78011.47
9	9.19	1.24	57.56	2.54	16.68	10.57	1.34	78736.61
10	8.19	2.90	55.94	2.88	15.86	11.13	1.31	74462.27
11	7.64	5.30	61.59	2.41	15.88	10.56	1.32	76657.87
12	7.41	4.08	56.42	2.37	15.60	10.94	1.31	74868.56
13	9.04	5.71	59.20	2.52	15.63	11.08	1.31	74098.52
14	4.01	3.83	62.49	1.95	16.66	10.83	1.33	72980.49
15	3.36	4.83	60.70	1.98	16.72	10.96	1.31	72993.04
16	4.39	5.28	52.37	1.96	16.69	10.35	1.31	80386.96
17	4.19	6.88	46.95	1.93	16.14	10.37	1.33	77952.03
18	3.61	27.11	48.36	1.90	17.83	9.94	1.31	76843.82
19	2.52	0.66	42.94	1.65	16.65	10.32	1.31	76664.38
20	5.16	9.59	57.50	3.05	16.77	10.18	1.32	76452.51
21	9.44	6.61	57.94	3.57	17.94	9.69	1.32	78480.69
22	7.31	3.79	52.29	4.25	17.82	9.56	1.30	76697.68
23	7.61	1.70	64.92	2.23	16.94	10.69	1.31	76917.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.71	4.69	52.37	2.32	16.76	10.46	1.32	76683.98
最 大 值	9.69	27.11	64.92	4.25	18.60	11.13	1.37	81414.30
發生時間	8	18	23	22	2	10		7
最 小 值	2.52	0.66	40.16	1.58	14.84	9.56	1.26	72980.49
發生時間	19	19	4	5	7	22		14
零點偏移(率)	-0.06 %	0.00 %	-0.04 %	-0.02 %		-0.01	0.00	0.00 %
全幅偏移(率)	3.72 %	0.74 %	-0.48 %	0.19 %		0.27	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								