

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年07月02日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.49	8.35	52.12	0.29	18.93	11.38	1.53	83027.23
1	12.05	7.37	45.20	0.42	18.19	11.56	1.52	82047.31
2	10.88	8.87	58.02	0.21	17.75	12.29	1.51	77022.88
3	12.79	11.93	42.53	0.42	17.63	11.72	1.52	82677.12
4	11.84	3.75	42.34	0.49	17.48	11.67	1.51	82114.83
5	11.06	6.95	59.54	0.49	16.54	11.85	1.51	83011.99
6	14.42	12.98	54.25	1.08	15.52	12.05	1.51	78984.94
7	14.36	5.97	52.29	0.83	16.72	11.91	1.51	80344.31
8	10.39	9.76	46.54	0.73	16.59	11.82	1.51	81063.90
9	11.27	13.65	48.14	0.91	16.38	12.06	1.52	79994.71
10	12.97	17.14	40.61	1.40	15.78	11.90	1.53	80310.13
11	1.46	3.15	47.12	0.28	16.26	11.78	1.52	82135.76
12	11.03	7.24	47.40	0.82	15.73	11.97	1.51	81207.48
13	11.39	5.66	43.90	0.91	15.44	12.00	1.51	81052.85
14	1.37	4.44	49.80	0.43	15.85	11.93	1.52	82146.98
15	11.04	8.48	44.97	1.30	15.40	11.93	1.53	82300.74
16	12.71	4.93	44.81	1.12	15.51	11.90	1.52	78085.39
17	14.97	1.82	50.88	0.64	17.80	11.43	1.51	82208.38
18	15.61	2.02	50.76	0.62	17.13	11.66	1.51	81411.32
19	11.49	7.46	50.52	0.63	16.43	11.81	1.51	83095.26
20	11.34	5.76	49.39	0.50	17.42	11.80	1.53	69338.42
21	12.41	1.14	48.19	0.54	17.45	11.69	1.51	65365.09
22	12.73	0.98	48.28	0.38	17.63	11.89	1.51	64308.04
23	14.08	2.75	54.37	0.52	17.06	12.37	1.52	62029.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.55	6.77	48.83	0.66	16.78	11.85	1.52	78553.52
最 大 值	15.61	17.14	59.54	1.40	18.93	12.37	1.57	83095.26
發生時間	18	10	5	10	0	23		19
最 小 值	1.37	0.98	40.61	0.21	15.40	11.38	1.50	62029.47
發生時間	14	22	10	2	15	0		23
零點偏移(率)	0.00 %	0.00 %	0.00 %	-0.01 %		-0.14	0.00	0.00 %
全幅偏移(率)	2.36 %	0.46 %	-0.39 %	0.61 %		0.23	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年07月02日

[illegible]

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 111年07月02日

[illegible]