

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 2020年07月06日

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
0	6.51	25.80	76.29	8.86	19.65	8.33	1.38	88667.59
1	8.98	10.81	74.37	8.00	20.31	8.58	1.38	85841.26
2	13.10	3.37	73.75	9.02	20.44	8.16	1.38	88824.16
3	14.86	9.51	83.79	9.53	18.90	8.90	1.36	82356.31
4	11.50	2.96	86.96	8.51	18.59	9.26	1.36	79916.79
5	7.65	14.23	82.06	7.92	21.15	8.01	1.38	87491.93
6	12.74	2.77	80.14	8.64	18.61	9.07	1.37	80916.17
7	10.30	無效	53.80	14.30	20.66	7.13	1.38	86323.49
8	18.98	42.63	59.53	9.78	17.67	8.99	1.41	74971.08
9	10.39	20.17	67.54	7.63	20.28	8.31	1.40	84504.83
10	8.72	20.89	80.97	6.60	21.91	8.47	1.41	87036.02
11	7.94	3.25	91.71	7.68	19.49	9.61	1.40	79540.88
12	14.06	2.66	94.16	7.69	19.52	9.39	1.44	89438.19
13	15.86	2.72	97.94	7.72	19.56	9.57	1.46	88699.55
14	18.20	13.50	83.39	7.47	20.69	8.63	1.44	84739.21
15	11.43	3.50	70.46	7.53	18.66	8.51	1.43	79477.50
16	13.68	2.81	73.56	8.05	18.65	8.61	1.44	78415.73
17	9.19	43.85	79.54	7.47	19.82	8.58	1.44	78917.08
18	10.84	9.48	98.00	7.52	19.40	9.23	1.43	80613.58
19	8.98	1.69	98.82	7.07	20.87	8.67	1.40	89023.30
20	10.05	12.36	94.54	7.61	19.03	9.55	1.39	90296.20
21	11.04	6.10	90.93	7.51	19.23	9.41	1.38	87569.29
22	9.30	15.06	80.81	6.85	20.72	8.63	1.38	85288.75
23	9.52	6.18	81.42	7.36	19.94	8.80	1.37	84556.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	23	24	24	24	24	24	24
平均值	11.41	12.01	81.44	8.18	19.74	8.77	1.40	84309.41
最大值	18.98	43.85	98.82	14.30	21.91	9.61	1.46	90296.20
發生時間	8	17	19	7	10	11		20
最小值	6.51	1.69	53.80	6.60	17.67	7.13	1.34	74971.08
發生時間	0	19	7	10	8	7		8
零點偏移	-0.02 %	0.00	-0.03 %	-0.04 %		0.01	-0.00	-0.01 %
全幅偏移	0.04 %	0.00	0.09 %	0.02 %		-0.03	-0.00	-0.01 %
有效比率	100.00 %	95.88%	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %