

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 111年05月30日

報表日期: 111年05月30日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	15.27	10.01	58.61	1.80	16.20	12.02	1.41	75935.47
1	16.50	18.96	51.29	2.02	15.22	12.37	1.40	75686.17
2	13.71	10.77	54.18	2.35	14.32	12.61	1.40	73142.27
3	12.77	8.59	63.10	2.34	14.53	12.56	1.37	72551.91
4	15.08	6.40	65.85	1.69	15.82	12.20	1.36	74298.09
5	15.33	13.36	57.26	1.94	15.57	11.70	1.39	78895.76
6	12.41	12.09	49.40	1.47	14.88	12.04	1.39	74133.29
7	14.87	11.16	49.48	1.90	15.77	11.85	1.42	76364.48
8	12.68	7.23	54.77	1.31	15.64	11.83	1.46	77314.54
9	15.07	13.51	47.81	1.94	14.58	12.07	1.44	74247.85
10	14.98	9.01	65.31	1.34	15.80	12.16	1.43	73855.72
11	14.63	6.16	71.64	1.20	15.74	12.30	1.48	75602.20
12	11.86	8.49	50.59	0.55	16.09	12.57	1.49	75056.53
13	13.76	22.71	49.13	1.07	15.46	12.20	1.50	78548.70
14	14.18	7.01	49.38	0.87	15.69	12.02	1.46	75148.79
15	11.91	8.84	58.11	0.71	15.94	12.07	1.47	76399.11
16	12.41	23.64	49.57	1.51	14.95	12.28	1.47	76617.41
17	14.32	5.65	51.28	0.98	15.60	12.11	1.46	76788.60
18	13.92	3.49	48.02	0.93	15.67	11.99	1.47	77249.47
19	13.70	12.35	53.77	0.92	15.72	11.88	1.47	78667.62
20	13.31	13.51	49.13	0.85	15.49	11.92	1.46	76360.97
21	15.32	7.88	48.00	0.85	15.52	11.68	1.44	76941.24
22	11.23	6.92	50.59	0.40	15.89	11.79	1.45	77014.94
23	13.22	5.12	63.81	0.32	16.62	12.07	1.48	75786.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	13.85	10.54	54.59	1.30	15.53	12.10	1.44	75941.99
最 大 值	16.50	23.64	71.64	2.35	16.62	12.61	1.52	78895.76
發生時間	1	16	11	2	23	2		5
最 小 值	11.23	3.49	47.81	0.32	14.32	11.68	1.33	72551.91
發生時間	22	18	9	23	2	21		3
零點偏移(率)	-0.18 %	-0.02 %	-0.04 %	-0.13 %		-0.08	0.00	0.00 %
全幅偏移(率)	3.70 %	0.45 %	-0.21 %	0.17 %		-0.13	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 111年05月30日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.40	5.52	46.98	0.16	21.55	9.96	1.43	96720.87
1	13.97	4.99	48.09	0.13	22.25	10.65	1.45	89152.45
2	14.19	14.95	54.85	0.13	20.22	10.34	1.46	93027.74
3	13.91	2.34	59.88	0.13	18.96	11.04	1.46	88522.03
4	14.32	3.04	53.26	0.11	18.09	11.06	1.45	85721.86
5	13.24	10.42	51.09	0.13	18.89	10.84	1.44	88242.90
6	6.73	3.14	59.29	0.14	17.50	11.55	1.46	82590.21
7	14.06	6.94	51.97	0.09	16.98	11.56	1.47	79370.26
8	13.27	1.77	60.46	0.13	18.59	10.62	1.46	90418.78
9	11.44	1.68	55.43	0.18	19.57	10.83	1.48	87741.40
10	12.74	3.35	55.40	0.18	19.77	10.61	1.49	88122.42
11	6.55	5.34	68.27	0.21	18.17	12.16	1.50	74111.91
12	8.40	5.55	52.14	0.18	19.92	10.64	1.52	88249.79
13	13.62	2.48	61.49	0.18	20.42	10.30	1.50	93405.39
14	12.96	2.56	52.54	0.18	20.56	10.34	1.50	93005.62
15	13.90	3.99	45.65	0.18	20.07	10.44	1.50	92782.31
16	14.53	2.60	55.07	0.15	18.73	10.60	1.49	93531.00
17	12.96	53.07	55.79	0.15	18.19	11.12	1.50	87765.76
18	12.46	5.33	58.98	0.18	19.19	11.10	1.49	86862.16
19	14.55	8.34	56.15	0.15	20.72	10.25	1.48	92948.78
20	14.11	6.28	53.42	0.13	18.64	10.51	1.49	91391.03
21	17.36	9.46	56.71	0.15	19.68	10.42	1.46	94223.47
22	14.13	6.31	53.63	0.17	19.41	10.73	1.46	90209.62
23	13.92	0.65	65.47	0.18	20.81	10.58	1.46	90575.80
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.99	7.09	55.50	0.15	19.45	10.76	1.47	89112.23
最 大 值	17.36	53.07	68.27	0.21	22.25	12.16	1.57	96720.87
發生時間	21	17	11	11	1	11		0
最 小 值	6.55	0.65	45.65	0.09	16.98	9.96	1.42	74111.91
發生時間	11	23	15	7	7	0		11
零點偏移(率)	-0.04 %	0.00 %	-0.02 %	-0.05 %		-0.17	0.00	0.00 %
全幅偏移(率)	2.32 %	0.03 %	0.01 %	0.21 %		0.06	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 111年05月30日

報表日期: 111年05月30日

項目 單位	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO ₂ _C	#3-H ₂ O	#3-O ₂ _C	#3-OPAC	#3-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.84	2.81	61.96	1.46	18.78	9.76	1.38	77267.34
1	14.50	8.57	65.22	1.29	17.65	9.99	1.38	74336.77
2	14.86	8.02	53.99	1.31	18.07	10.25	1.38	66095.48
3	13.83	15.31	56.26	1.76	20.39	9.15	1.38	72764.40
4	14.76	12.74	53.28	2.70	18.18	8.62	1.38	75870.82
5	14.35	7.65	59.68	2.27	15.76	10.32	1.37	72931.65
6	12.72	6.00	59.36	1.42	17.61	10.01	1.39	72992.69
7	13.48	4.77	53.12	1.62	16.30	10.14	1.39	74151.35
8	13.88	7.43	51.06	1.61	18.57	9.57	1.39	73959.44
9	14.25	22.63	60.16	1.44	18.47	9.84	1.38	68877.89
10	14.72	4.54	65.52	1.67	18.79	9.36	1.37	71796.31
11	13.27	4.41	65.69	1.07	18.70	10.18	1.36	67243.61
12	13.70	9.03	62.09	0.88	19.14	10.63	1.36	67760.78
13	13.82	6.93	49.00	1.21	18.88	9.58	1.36	75221.93
14	13.99	7.76	50.35	1.90	15.79	11.25	1.35	74368.91
15	14.23	3.83	49.38	1.34	17.17	10.47	1.37	72542.79
16	11.25	3.93	57.05	0.92	17.47	10.84	1.38	66695.78
17	11.86	7.08	78.49	0.95	16.71	12.23	1.38	57133.33
18	14.48	2.06	63.10	0.71	20.59	9.81	1.36	71709.86
19	14.55	7.96	50.99	1.35	18.29	9.55	1.38	77321.61
20	14.27	11.91	47.52	1.38	15.95	10.20	1.38	73872.09
21	14.57	1.87	56.22	1.40	16.23	10.55	1.38	72053.17
22	15.25	6.63	53.34	1.37	16.18	10.45	1.37	72300.23
23	14.32	3.37	65.09	1.33	18.05	10.32	1.38	73640.51
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	13.95	7.39	57.83	1.43	17.82	10.13	1.37	71787.86
最 大 值	15.25	22.63	78.49	2.70	20.59	12.23	1.41	77321.61
發生時間	22	9	17	4	18	17		19
最 小 值	11.25	1.87	47.52	0.71	15.76	8.62	1.34	57133.33
發生時間	16	21	20	18	5	4		17
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	-0.06 %		-0.03	0.00	0.00 %
全幅偏移(率)	1.88 %	0.03 %	-0.51 %	0.17 %		-0.11	0.00	0.20 %
有效率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								