

報表日期: 111年08月19日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.32	3.45	59.65	0.12	17.77	11.21	1.45	80383.80
1	9.67	4.61	63.56	0.14	17.18	11.87	1.46	78237.40
2	11.87	4.41	56.74	0.17	19.40	11.40	1.46	81719.47
3	13.37	6.57	63.45	0.40	18.18	10.46	1.45	90547.22
4	13.07	1.51	69.59	0.22	17.38	11.07	1.45	86227.91
5	12.82	4.89	53.13	0.19	17.13	11.28	1.45	83426.99
6	11.69	2.37	56.50	0.16	16.85	11.67	1.46	77149.81
7	13.00	1.31	61.81	0.19	18.06	10.99	1.47	84669.70
8	12.99	3.03	47.32	0.62	16.54	10.86	1.46	84766.40
9	11.53	2.30	55.77	0.29	15.90	11.57	1.46	79962.66
10	11.26	9.48	61.41	0.60	15.61	11.19	1.48	85326.38
11	11.82	9.37	57.48	0.61	15.15	11.07	1.48	86999.69
12	13.02	0.74	58.60	0.66	16.40	10.95	1.47	88103.12
13	14.27	13.37	61.18	1.48	16.62	10.91	1.48	87102.77
14	13.36	8.82	56.05	2.05	16.25	10.80	1.46	85995.98
15	13.04	5.18	62.03	1.46	16.62	10.92	1.46	86047.95
16	15.62	9.22	62.43	4.53	15.08	11.28	1.45	84157.52
17	11.94	4.03	63.46	0.62	17.04	11.24	1.45	81639.42
18	11.67	5.17	52.98	0.24	17.16	10.97	1.45	81767.47
19	12.73	3.26	57.01	0.30	17.02	11.10	1.46	80855.10
20	11.79	3.35	59.50	0.29	17.38	11.21	1.46	80258.59
21	10.42	4.59	54.96	0.20	17.73	11.17	1.47	81442.59
22	8.41	4.62	56.12	0.12	17.85	11.48	1.48	80125.17
23	13.44	12.54	47.70	0.42	17.07	10.67	1.47	87045.45
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.30	5.34	58.27	0.67	16.97	11.14	1.46	83498.27
最 大 值	15.62	13.37	69.59	4.53	19.40	11.87	1.49	90547.22
發生時間	16	13	4	16	2	1		3
最 小 值	8.41	0.74	47.32	0.12	15.08	10.46	1.43	77149.81
發生時間	22	12	8	0	16	3		6
零點偏移(率)	-0.24 %	-0.03 %	-0.02 %	-0.02 %		-0.04	0.00	0.00 %
全幅偏移(率)	0.92 %	0.19 %	-0.32 %	0.05 %		0.19	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月19日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.21	6.41	53.81	0.93	17.44	11.13	1.52	63968.83
1	0.12	5.03	57.30	0.98	17.53	11.26	1.53	62594.76
2	0.39	11.55	54.69	0.86	20.08	9.95	1.54	73317.97
3	7.29	10.76	47.32	1.87	16.54	10.23	1.53	72776.60
4	9.09	7.53	42.36	2.17	16.78	10.23	1.48	70830.18
5	0.77	3.80	45.99	1.02	17.19	10.76	1.50	66122.31
6	0.34	9.24	42.71	0.94	18.09	9.98	1.50	70804.57
7	2.07	8.28	49.69	1.37	17.95	10.31	1.53	67212.21
8	3.85	13.57	48.72	1.62	16.88	10.44	1.57	70991.89
9	5.17	8.51	47.79	1.78	16.60	10.49	1.55	71025.38
10	6.94	9.10	46.84	1.84	15.98	10.74	1.52	70140.63
11	14.43	13.59	49.66	3.15	15.97	10.26	1.53	72754.06
12	13.29	3.73	60.03	2.46	17.25	10.19	1.58	72586.04
13	13.36	3.35	69.44	3.09	17.16	10.03	1.60	72176.52
14	8.91	6.92	68.55	2.09	17.30	11.24	1.56	61161.63
15	9.38	2.25	67.05	1.63	17.22	11.39	1.54	59777.95
16	12.50	4.38	60.27	2.06	16.14	11.56	1.57	61197.96
17	13.84	15.02	51.09	1.85	17.23	10.20	1.53	72242.53
18	13.67	10.54	52.83	2.32	17.81	10.13	1.52	71815.93
19	12.96	3.86	61.51	2.35	16.92	10.46	1.54	68748.61
20	14.65	13.17	53.10	2.57	15.67	10.69	1.54	71347.90
21	12.59	9.09	53.32	2.39	14.78	11.58	1.54	63865.87
22	14.69	2.94	52.11	2.10	16.08	11.16	1.55	63764.01
23	11.93	4.91	51.49	1.56	16.70	11.12	1.55	63770.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.44	7.81	53.65	1.88	16.97	10.65	1.54	68124.77
最 大 值	14.69	15.02	69.44	3.15	20.08	11.58	1.61	73317.97
發生時間	22	17	13	11	2	21		2
最 小 值	0.12	2.25	42.36	0.86	14.78	9.95	1.45	59777.95
發生時間	1	15	4	2	21	2		15
零點偏移(率)	-0.01 %	-0.03 %	-0.02 %	0.00 %		0.03	0.00	0.00 %
全幅偏移(率)	4.32 %	0.08 %	-0.31 %	0.01 %		0.18	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								