

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 111年10月08日

報表日期: 111年10月08日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	10.73	4.55	61.54	0.05	17.93	11.65	1.34	71176.28
1	12.21	4.49	49.42	0.16	18.90	11.12	1.33	73835.58
2	10.13	6.62	55.35	0.22	16.88	11.85	1.33	70386.01
3	11.59	5.51	52.66	0.25	17.12	11.55	1.34	72750.65
4	10.54	4.74	55.15	0.32	16.78	11.48	1.34	73343.96
5	6.26	3.87	61.12	0.13	17.81	11.19	1.33	69214.79
6	11.96	4.64	49.21	0.29	17.38	11.30	1.34	74071.64
7	9.91	5.06	52.44	0.27	16.23	11.79	1.36	71681.77
8	11.03	11.72	57.00	0.37	16.58	12.21	1.34	68624.29
9	10.12	5.63	47.56	0.46	17.07	11.18	1.33	74709.09
10	10.75	5.15	48.25	0.46	16.79	11.30	1.33	73870.19
11	10.26	8.35	44.99	0.42	17.12	11.17	1.33	74974.83
12	11.73	2.16	48.47	1.04	15.35	11.67	1.33	72725.06
13	11.42	4.78	44.25	1.34	14.50	11.82	1.33	71872.21
14	11.93	2.35	49.23	1.08	15.49	11.78	1.37	71730.74
15	11.82	7.07	43.83	1.69	14.52	11.78	1.37	72592.54
16	10.57	7.87	44.55	1.55	14.50	11.81	1.37	72554.62
17	11.29	2.77	47.93	1.27	14.98	11.88	1.39	71420.67
18	8.51	0.94	53.50	0.54	15.88	11.83	1.41	72908.93
19	12.09	4.57	44.53	0.30	17.06	11.24	1.40	76888.26
20	10.31	2.49	44.21	0.46	16.48	11.43	1.39	73839.25
21	11.07	2.75	47.55	0.65	16.61	11.47	1.39	73442.21
22	10.94	1.69	55.87	0.23	16.93	11.82	1.39	71166.93
23	10.93	2.58	57.44	0.62	16.25	11.88	1.39	70152.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.75	4.68	50.67	0.59	16.46	11.59	1.36	72497.22
最 大 值	12.21	11.72	61.54	1.69	18.90	12.21	1.41	76888.26
發生時間	1	8	0	15	1	8		19
最 小 值	6.26	0.94	43.83	0.05	14.50	11.12	1.33	68624.29
發生時間	5	18	15	0	13	1		8
零點偏移(率)	-0.09 %	-0.02 %	-0.01 %	-0.01 %		0.02	0.00	0.00 %
全幅偏移(率)	-0.65 %	-3.04 %	0.20 %	-1.75 %		0.25	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 111年10月08日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.64	3.11	62.60	0.16	19.49	10.17	1.41	93492.55
1	10.70	4.31	49.96	0.12	18.06	10.54	1.42	91405.17
2	11.14	3.05	56.01	0.13	18.18	10.54	1.41	91543.68
3	10.72	1.75	65.97	0.16	18.79	10.96	1.41	87958.25
4	11.29	2.74	47.74	0.12	18.59	10.16	1.41	93980.70
5	11.74	3.86	53.18	0.12	18.56	10.05	1.42	95395.00
6	19.23	2.90	62.82	0.67	17.82	11.16	1.42	87083.58
7	10.51	4.54	70.15	0.10	17.24	11.58	1.41	83460.80
8	11.39	3.29	62.73	0.13	18.11	10.96	1.41	88235.21
9	10.62	5.10	55.94	0.10	17.38	11.03	1.42	88202.45
10	11.36	4.69	50.16	0.20	17.03	10.58	1.40	92077.75
11	9.51	3.60	67.78	0.13	18.05	11.41	1.39	88974.05
12	14.89	4.53	54.60	1.13	17.20	11.52	1.39	92000.95
13	7.78	2.96	54.79	2.41	16.54	11.84	1.38	90171.97
14	9.80	1.89	56.25	7.53	17.02	11.87	1.38	91524.81
15	11.08	7.77	61.69	2.64	16.02	12.23	1.38	89015.01
16	9.52	3.40	60.91	1.55	17.21	11.90	1.38	91743.45
17	4.58	2.15	66.31	0.68	18.10	12.05	1.39	90490.91
18	9.20	1.42	54.89	0.58	17.14	11.62	1.41	91646.88
19	9.16	5.76	59.85	0.47	16.32	12.23	1.44	84143.67
20	11.65	1.58	52.55	0.28	17.27	11.05	1.44	91757.98
21	10.64	6.76	67.09	0.12	16.17	12.53	1.44	78972.49
22	10.56	1.70	52.88	0.13	18.17	10.82	1.43	91434.77
23	11.69	8.53	64.30	0.11	16.20	12.22	1.43	81164.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.85	3.81	58.80	0.82	17.53	11.29	1.41	89411.54
最 大 值	19.23	8.53	70.15	7.53	19.49	12.53	1.45	95395.00
發生時間	6	23	7	14	0	21		5
最 小 值	4.58	1.42	47.74	0.10	16.02	10.05	1.38	78972.49
發生時間	17	18	4	7	15	5		21
零點偏移(率)	-0.05 %	0.00 %	-0.13 %	-0.01 %		0.03	0.00	0.00 %
全幅偏移(率)	0.03 %	0.00 %	-0.20 %	-0.05 %		0.18	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

