

報表日期: 111年06月07日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.89	7.10	51.65	0.29	18.32	11.35	1.46	83017.55
1	13.91	6.97	52.64	0.32	17.88	11.54	1.47	82003.26
2	15.39	7.07	51.18	0.31	18.40	11.52	1.48	81959.96
3	13.28	8.34	48.06	0.49	18.19	11.38	1.49	83348.65
4	12.16	10.38	43.92	1.19	15.54	11.99	1.49	76389.11
5	14.64	9.15	52.12	0.75	17.53	12.16	1.53	77437.78
6	14.01	4.07	48.53	0.61	17.48	11.68	1.51	80288.81
7	12.81	5.99	47.54	0.49	17.37	11.72	1.51	80116.38
8	14.07	19.53	46.26	0.72	16.29	12.10	1.51	77695.68
9	12.87	11.41	42.22	0.59	17.19	11.75	1.51	78376.85
10	10.30	14.54	40.14	0.57	15.94	12.22	1.51	73569.69
11	13.85	12.53	48.97	0.75	16.93	11.69	1.51	77619.72
12	12.79	8.15	44.48	0.68	16.68	11.51	1.51	78663.99
13	12.38	12.85	39.36	0.88	15.82	11.78	1.51	76513.90
14	15.65	20.48	37.51	1.54	15.67	11.69	1.53	77208.51
15	16.87	9.00	32.40	2.33	14.89	11.48	1.51	76950.06
16	12.79	10.41	30.02	1.41	14.88	11.72	1.51	73288.70
17	13.53	3.54	37.50	0.63	17.76	11.31	1.49	79278.22
18	14.91	7.41	54.00	0.59	16.85	11.89	1.51	78075.11
19	12.35	11.98	55.55	0.72	16.53	11.96	1.55	79485.62
20	15.05	12.30	58.47	1.10	16.63	12.01	1.54	77909.33
21	14.63	13.00	45.10	1.75	14.80	11.95	1.51	78899.26
22	13.62	6.26	46.38	1.38	15.75	12.03	1.51	77865.27
23	14.62	5.41	42.33	1.10	15.75	11.99	1.51	78309.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	13.72	9.91	45.68	0.88	16.63	11.77	1.51	78511.27
最 大 值	16.87	20.48	58.47	2.33	18.40	12.22	1.56	83348.65
發生時間	15	14	20	15	2	10		3
最 小 值	10.30	3.54	30.02	0.29	14.80	11.31	1.46	73288.70
發生時間	10	17	16	0	21	17		16
零點偏移(率)	-0.13 %	-0.03 %	-0.05 %	-0.02 %		-0.27	0.00	0.00 %
全幅偏移(率)	3.17 %	0.04 %	-0.20 %	0.03 %		-0.06	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 111年06月07日

[illegible]

