

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 111年10月01日

報表日期: 111年10月01日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.97	5.26	49.60	0.14	19.30	11.14	1.33	71529.66
1	11.45	10.03	44.21	0.13	18.45	11.73	1.33	68054.36
2	10.72	1.96	49.88	0.13	18.60	11.53	1.33	70249.15
3	11.54	1.57	53.54	0.11	18.04	11.79	1.33	68388.35
4	9.35	3.05	56.50	0.15	18.68	11.69	1.32	69137.40
5	1.61	3.77	46.82	0.17	18.52	11.40	1.33	75225.19
6	11.90	7.67	44.07	0.17	20.19	11.09	1.33	72281.58
7	10.73	6.99	39.92	0.16	21.26	10.59	1.33	74448.20
8	9.41	1.36	42.78	0.17	21.16	10.91	1.36	72079.94
9	11.46	5.18	36.93	0.13	21.36	10.49	1.33	75140.61
10	12.04	3.42	40.18	0.17	19.70	11.30	1.35	70492.62
11	10.51	2.76	40.54	0.14	18.60	11.31	1.35	71541.34
12	10.51	8.57	41.46	0.12	17.29	11.80	1.33	68447.77
13	10.09	10.53	37.17	0.13	18.17	11.45	1.34	70411.99
14	12.03	4.31	45.50	0.16	18.16	11.71	1.33	68891.96
15	10.81	5.32	40.58	0.16	18.13	11.63	1.33	68911.90
16	13.84	6.35	40.85	0.12	17.22	11.77	1.33	68404.47
17	8.60	6.51	40.78	0.15	18.32	11.61	1.33	69079.08
18	11.36	2.54	50.51	0.17	18.74	11.78	1.35	67669.94
19	11.00	2.24	55.06	0.17	19.35	11.44	1.36	69765.36
20	11.00	8.53	44.23	0.12	17.54	11.65	1.33	69944.01
21	11.54	6.32	52.99	0.16	19.71	11.12	1.31	72073.10
22	10.10	1.59	42.37	0.15	17.60	11.78	1.30	68984.14
23	10.88	4.88	46.83	0.17	18.55	11.90	1.32	67609.11
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.56	5.03	45.14	0.15	18.86	11.44	1.33	70365.05
最 大 值	13.84	10.53	56.50	0.17	21.36	11.90	1.38	75225.19
發生時間	16	13	4	5	9	23		5
最 小 值	1.61	1.36	36.93	0.11	17.22	10.49	1.29	67609.11
發生時間	5	8	9	3	16	9		23
零點偏移(率)	-0.01 %	-0.01 %	-0.07 %	-0.02 %		0.03	0.00	0.00 %
全幅偏移(率)	0.00 %	0.02 %	-0.23 %	0.02 %		0.37	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 111年10月01日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	8.46	7.68	65.61	0.14	16.99	12.33	1.45	75208.38
1	10.76	1.55	47.56	0.17	18.86	10.93	1.43	85409.09
2	11.60	1.17	48.64	0.15	18.85	10.71	1.43	87377.14
3	10.99	3.05	52.69	0.16	19.66	10.46	1.43	88788.40
4	11.08	1.35	44.00	0.15	19.25	10.50	1.43	88600.90
5	7.44	4.04	63.05	0.18	18.19	12.29	1.43	74858.21
6	10.64	6.52	39.63	0.16	21.25	10.13	1.43	80579.30
7	12.22	4.54	43.56	0.14	18.82	10.64	1.43	87920.09
8	10.29	0.67	51.20	0.16	18.29	11.19	1.45	83640.76
9	11.62	0.95	51.61	0.17	19.83	10.69	1.46	86353.76
10	11.08	4.39	45.87	0.13	17.94	10.93	1.45	86082.74
11	11.19	4.32	55.37	0.12	17.72	10.84	1.45	86383.51
12	10.89	4.92	50.03	0.11	17.10	11.13	1.47	85153.60
13	11.09	4.65	47.72	0.14	17.84	11.27	1.48	82977.56
14	9.93	10.60	55.76	0.13	16.80	12.07	1.46	74637.27
15	12.62	6.75	42.77	0.11	16.68	11.64	1.45	77613.88
16	9.93	6.27	41.86	0.16	18.82	10.76	1.45	86434.41
17	10.84	1.00	57.33	0.16	18.03	11.35	1.45	81810.48
18	11.11	1.45	47.44	0.17	18.24	10.86	1.45	85814.29
19	10.69	1.83	49.99	0.14	17.29	11.27	1.43	84348.97
20	11.07	2.46	47.51	0.12	16.87	11.25	1.43	83759.63
21	11.12	7.08	56.65	0.18	18.98	11.10	1.44	83892.95
22	10.06	0.44	47.41	0.19	19.47	10.79	1.44	86101.39
23	11.01	1.96	48.20	0.19	19.02	11.01	1.44	84433.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.74	3.73	50.06	0.15	18.37	11.09	1.44	83674.16
最 大 值	12.62	10.60	65.61	0.19	21.25	12.33	1.49	88788.40
發生時間	15	14	0	22	6	0		3
最 小 值	7.44	0.44	39.63	0.11	16.68	10.13	1.41	74637.27
發生時間	5	22	6	12	15	6		14
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	-0.04 %		0.05	0.00	0.00 %
全幅偏移(率)	0.13 %	2.29 %	0.19 %	0.52 %		0.08	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

