

報表日期: 111年12月07日

| 項目<br>單位<br>小時\限標 | #1-HCl_C | #1-CO_C  | #1-NOx_C | #1-SO2_C | #1-H2O   | #1-O2_C  | #1-OPAC  | #1-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 5.88     | 3.66     | 62.89    | 1.07     | 19.17    | 11.72    | 1.40     | 74124.95  |
| 1                 | 5.57     | 4.66     | 55.11    | 1.00     | 19.75    | 11.84    | 1.37     | 73111.69  |
| 2                 | 10.76    | 4.31     | 59.06    | 1.49     | 19.08    | 11.70    | 1.35     | 74941.21  |
| 3                 | 11.16    | 8.93     | 55.11    | 1.71     | 17.80    | 11.72    | 1.36     | 75472.70  |
| 4                 | 8.28     | 9.69     | 58.12    | 1.60     | 17.70    | 11.95    | 1.39     | 73584.96  |
| 5                 | 1.72     | 7.63     | 68.71    | 1.37     | 17.58    | 12.18    | 1.40     | 72875.10  |
| 6                 | 7.02     | 6.29     | 59.93    | 1.61     | 18.45    | 12.23    | 1.39     | 71083.34  |
| 7                 | 8.64     | 10.88    | 58.34    | 1.75     | 17.46    | 12.44    | 1.38     | 69978.61  |
| 8                 | 10.07    | 6.70     | 57.79    | 1.56     | 17.89    | 11.81    | 1.35     | 74474.01  |
| 9                 | 8.87     | 4.36     | 67.23    | 1.31     | 19.07    | 11.32    | 1.33     | 76556.46  |
| 10                | 9.36     | 6.67     | 53.82    | 1.46     | 18.13    | 11.63    | 1.33     | 74693.38  |
| 11                | 2.50     | 7.45     | 60.96    | 1.14     | 18.56    | 11.73    | 1.39     | 73541.48  |
| 12                | 4.17     | 9.36     | 62.60    | 1.08     | 19.22    | 11.46    | 1.39     | 74814.90  |
| 13                | 9.37     | 10.14    | 48.60    | 1.08     | 19.53    | 10.85    | 1.36     | 79216.19  |
| 14                | 9.56     | 3.76     | 57.01    | 1.42     | 18.41    | 11.38    | 1.35     | 76231.95  |
| 15                | 8.77     | 4.87     | 57.90    | 1.33     | 18.37    | 11.47    | 1.33     | 75528.13  |
| 16                | 11.05    | 9.00     | 52.64    | 1.55     | 17.89    | 11.55    | 1.33     | 74516.11  |
| 17                | 9.34     | 16.01    | 51.64    | 1.69     | 17.67    | 11.78    | 1.34     | 73404.34  |
| 18                | 21.59    | 4.36     | 55.69    | 2.18     | 17.70    | 11.39    | 1.39     | 77534.37  |
| 19                | 10.62    | 6.09     | 48.67    | 1.73     | 17.82    | 11.43    | 1.41     | 75465.12  |
| 20                | 11.99    | 6.21     | 47.96    | 1.61     | 18.40    | 11.25    | 1.41     | 77019.60  |
| 21                | 9.28     | 6.78     | 57.77    | 1.73     | 17.31    | 11.87    | 1.41     | 73464.51  |
| 22                | 8.65     | 2.72     | 54.50    | 1.23     | 19.21    | 11.11    | 1.41     | 78879.15  |
| 23                | 8.61     | 1.57     | 61.10    | 1.42     | 17.98    | 11.68    | 1.41     | 74541.77  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 8.87     | 6.75     | 57.21    | 1.46     | 18.34    | 11.65    | 1.37     | 74793.92  |
| 最 大 值             | 21.59    | 16.01    | 68.71    | 2.18     | 19.75    | 12.44    | 1.43     | 79216.19  |
| 發生時間              | 18       | 17       | 5        | 18       | 1        | 7        |          | 13        |
| 最 小 值             | 1.72     | 1.57     | 47.96    | 1.00     | 17.31    | 10.85    | 1.33     | 69978.61  |
| 發生時間              | 5        | 23       | 20       | 1        | 21       | 13       |          | 7         |
| 零點偏移(率)           | 0.00 %   | -0.02 %  | -0.01 %  | 0.00 %   |          | 0.02     | 0.00     | 0.00 %    |
| 全幅偏移(率)           | 0.02 %   | 0.61 %   | -0.65 %  | 0.03 %   |          | 0.28     | 0.00     | 0.30 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月07日

[illegible]

