

報表日期: 111年08月11日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.71	4.39	50.68	0.30	17.92	10.63	1.51	62144.78
1	12.22	4.21	67.12	0.35	18.20	10.87	1.52	62573.72
2	11.79	8.60	53.38	0.24	17.30	11.14	1.51	58022.30
3	13.34	2.19	59.47	0.55	17.51	10.94	1.51	60298.33
4	14.00	5.10	55.76	0.69	16.62	11.01	1.51	61409.35
5	14.19	5.73	65.24	0.39	18.17	10.66	1.51	64480.11
6	12.07	1.74	60.22	0.24	16.96	10.97	1.50	66697.32
7	14.37	3.38	52.65	0.19	17.81	10.63	1.51	62216.53
8	13.82	0.96	56.80	0.14	18.64	10.64	1.50	63277.66
9	13.29	1.42	59.83	0.22	16.51	11.23	1.50	61869.94
10	13.68	0.45	60.59	0.11	18.91	10.71	1.50	62328.48
11	14.87	0.93	64.36	0.25	16.99	10.67	1.50	63839.57
12	14.14	0.61	67.81	0.42	16.87	10.88	1.51	63618.50
13	12.60	3.70	60.36	0.24	17.34	10.98	1.53	60223.25
14	14.39	2.66	66.00	0.27	16.41	10.95	1.53	62938.25
15	13.95	1.31	60.91	0.21	16.93	10.98	1.52	62895.87
16	14.29	0.73	51.68	0.18	16.97	10.94	1.53	62834.39
17	11.59	4.13	61.28	0.09	16.84	11.29	1.52	58858.67
18	7.98	1.39	69.49	0.09	15.86	12.23	1.50	52236.09
19	11.34	1.52	58.16	0.16	18.33	11.31	1.50	58550.75
20	13.58	3.38	56.85	0.13	18.45	10.44	1.51	64816.70
21	12.61	0.33	56.92	0.14	19.17	10.70	1.50	63213.33
22	12.77	0.63	54.72	0.16	19.36	10.36	1.50	63874.30
23	9.30	1.45	68.97	0.18	17.87	12.13	1.50	54594.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.95	2.54	59.97	0.25	17.58	10.97	1.51	61575.54
最 大 值	14.87	8.60	69.49	0.69	19.36	12.23	1.54	66697.32
發生時間	11	2	18	4	22	18		6
最 小 值	7.98	0.33	50.68	0.09	15.86	10.36	1.49	52236.09
發生時間	18	21	0	17	18	22		18
零點偏移(率)	-0.05 %	-0.01 %	-0.04 %	-0.05 %		-0.03	0.00	-0.20 %
全幅偏移(率)	1.08 %	0.61 %	-0.07 %	0.19 %		0.04	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月11日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.74	5.81	61.08	2.52	16.41	11.17	1.63	69825.21
1	14.29	2.82	56.34	3.13	18.27	10.13	1.63	71864.92
2	14.34	10.84	50.78	3.68	15.83	10.18	1.63	72380.47
3	10.04	6.33	60.39	2.87	17.29	10.39	1.66	71239.95
4	13.30	13.66	55.14	3.23	15.81	10.32	1.66	71976.36
5	13.86	5.18	53.01	2.91	16.69	10.08	1.65	74161.00
6	14.58	8.52	55.61	3.19	17.03	9.95	1.66	73753.86
7	13.91	8.04	47.07	3.22	15.32	10.30	1.63	69172.58
8	12.70	2.52	49.39	2.85	18.50	9.70	1.66	73677.61
9	13.52	2.79	52.07	2.62	18.72	9.69	1.68	75140.35
10	8.96	2.20	59.52	2.31	19.64	9.50	1.66	74697.96
11	14.01	1.83	54.15	2.85	18.15	9.52	1.65	75942.56
12	13.93	4.67	53.05	2.54	15.88	10.26	1.68	74286.02
13	12.04	3.30	53.52	2.29	16.35	10.43	1.69	71310.28
14	14.26	4.12	52.92	2.26	16.73	9.98	1.67	71840.39
15	13.48	1.89	56.32	2.41	16.32	10.48	1.67	69574.82
16	11.65	2.31	56.73	2.17	18.26	9.62	1.71	73878.47
17	13.29	0.73	65.08	2.31	17.15	9.97	1.71	78069.20
18	12.40	1.16	59.10	2.38	17.02	9.86	1.69	79484.13
19	11.71	1.21	59.40	2.00	17.35	10.65	1.65	69587.35
20	12.31	1.18	54.98	2.10	18.42	10.01	1.66	74446.62
21	14.02	2.53	63.38	2.68	17.79	9.89	1.70	80181.11
22	13.50	3.79	49.06	2.17	18.75	9.66	1.71	74027.76
23	10.94	1.33	64.34	2.08	18.32	10.94	1.70	65312.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.87	4.12	55.93	2.62	17.33	10.11	1.67	73159.65
最 大 值	14.58	13.66	65.08	3.68	19.64	11.17	1.73	80181.11
發生時間	6	4	17	2	10	0		21
最 小 值	8.96	0.73	47.07	2.00	15.32	9.50	1.62	65312.67
發生時間	10	17	7	19	7	10		23
零點偏移(率)	-0.01 %	-0.01 %	-0.02 %	-0.02 %		0.03	0.00	0.00 %
全幅偏移(率)	0.53 %	0.04 %	-0.47 %	0.04 %		0.21	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								