

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年07月03日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 111年07月03日

項目 單位	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO ₂ _C	#2-H ₂ O	#2-O ₂ _C	#2-OPAC	#2-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
0	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
1	12.58	1.95	56.24	0.62	15.99	11.35	1.38	83146.40
2	12.46	3.56	54.18	0.15	19.74	10.65	1.39	87714.62
3	11.72	7.02	55.37	0.20	18.89	10.79	1.40	85952.83
4	11.22	10.12	52.29	0.34	18.15	10.69	1.40	88908.71
5	14.40	0.76	56.86	0.14	18.14	10.80	1.39	86284.76
6	12.51	4.89	57.18	0.14	19.42	10.24	1.40	89752.70
7	9.53	1.28	63.42	0.11	18.89	10.40	1.45	98129.40
8	12.71	2.00	57.01	0.13	18.63	10.64	1.45	87876.41
9	13.44	15.78	54.28	0.14	20.39	10.05	1.45	89669.90
10	14.25	2.64	66.17	0.30	17.65	10.56	1.46	90136.27
11	12.21	1.31	52.51	0.17	18.37	10.85	1.46	86812.20
12	10.61	1.09	67.36	0.24	18.27	11.27	1.45	82350.72
13	15.10	1.70	59.89	0.46	19.50	10.26	1.45	91143.13
14	11.72	2.33	57.02	0.43	17.94	10.65	1.44	88917.67
15	14.52	4.05	51.60	0.41	16.66	11.12	1.44	87823.98
16	13.20	11.18	56.20	0.64	16.02	11.48	1.43	85506.97
17	10.86	3.11	61.93	0.13	17.33	11.62	1.43	78829.74
18	12.61	7.87	53.17	0.08	17.32	11.23	1.44	82223.11
19	13.49	3.11	57.71	0.16	17.23	11.10	1.45	83162.82
20	13.71	5.40	52.45	0.35	16.30	11.00	1.45	83987.78
21	12.68	4.36	49.57	0.33	17.01	10.74	1.45	84253.26
22	14.45	8.77	57.02	0.21	17.87	10.82	1.46	86316.17
23	11.55	1.68	58.25	0.30	16.25	11.20	1.45	85136.06
24	13.97	3.98	52.00	0.21	17.13	10.88	1.45	85609.61
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均値	12.73	4.58	56.65	0.27	17.88	10.85	1.43	86651.88
最大値	15.10	15.78	67.36	0.64	20.39	11.62	1.46	98129.40
發生時間	12	8	11	15	8	16		6
最小値	9.53	0.76	49.57	0.08	15.99	10.05	1.38	78829.74
發生時間	6	4	20	17	0	8		16
零點偏移(率)	-0.03 %	-0.00 %	-0.01 %	-0.04 %		-0.21	0.00	0.00 %
全幅偏移(率)	1.88 %	0.29 %	-0.27 %	0.43 %		0.30	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 111年07月03日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.96	2.14	47.82	1.51	17.04	10.04	1.42	73867.52
1	11.53	1.57	54.52	1.61	18.22	10.43	1.42	70398.56
2	15.52	2.78	52.95	2.04	17.90	9.85	1.41	71717.24
3	12.49	6.03	46.61	1.86	17.71	9.93	1.41	73102.25
4	13.73	1.24	52.32	1.76	18.03	10.22	1.43	70278.77
5	15.07	2.63	49.43	2.05	17.93	9.79	1.43	73687.60
6	10.50	5.18	47.09	1.73	17.17	9.78	1.43	74001.88
7	12.43	7.07	49.69	1.84	17.63	9.59	1.42	72688.27
8	13.65	2.83	53.95	2.08	15.80	10.37	1.42	76166.45
9	13.39	3.09	60.32	1.93	16.99	10.24	1.42	76046.59
10	13.66	2.46	52.36	1.91	16.86	10.10	1.41	74844.22
11	12.21	1.16	63.59	1.84	18.58	10.01	1.43	75307.10
12	13.27	3.38	63.39	2.23	16.19	10.19	1.45	74350.87
13	13.84	5.80	55.63	1.93	17.08	10.22	1.45	75003.76
14	16.25	7.64	54.24	2.13	15.91	10.45	1.44	73897.46
15	14.14	3.91	57.99	2.00	17.34	10.25	1.43	76339.37
16	9.52	7.82	66.52	1.86	17.82	10.01	1.44	77046.31
17	14.70	2.38	54.77	2.23	16.34	10.85	1.44	75355.13
18	12.50	2.57	55.86	1.86	17.24	10.62	1.44	72282.79
19	14.79	1.82	56.49	2.26	16.33	10.58	1.42	74246.69
20	13.04	1.96	53.20	2.15	16.24	10.55	1.39	71339.88
21	13.10	1.87	66.31	1.89	17.10	10.71	1.40	68434.74
22	17.38	2.57	57.34	2.37	16.83	9.80	1.41	72945.78
23	13.38	12.49	50.70	2.11	15.77	9.94	1.40	74322.34
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	13.42	3.85	55.13	1.97	17.09	10.19	1.42	73652.98
最 大 值	17.38	12.49	66.52	2.37	18.58	10.85	1.47	77046.31
發生時間	22	23	16	22	11	17		16
最 小 值	9.52	1.16	46.61	1.51	15.77	9.59	1.38	68434.74
發生時間	16	11	3	0	23	7		21
零點偏移(率)	-0.03 %	0.00 %	-0.00 %	-0.01 %		-0.11	0.00	0.00 %
全幅偏移(率)	2.94 %	0.54 %	-0.23 %	0.27 %		0.28	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								