

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 111年06月25日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.33	4.70	58.32	1.74	16.89	12.04	1.54	80346.95
1	11.61	7.98	63.82	1.59	16.79	12.44	1.54	76833.68
2	13.46	5.73	59.90	2.04	16.07	12.14	1.51	80272.09
3	15.90	7.13	62.17	2.63	15.83	12.10	1.51	80776.22
4	15.51	21.13	61.58	2.61	15.66	11.96	1.51	82046.69
5	6.94	12.98	56.85	1.54	15.82	12.09	1.51	87107.86
6	8.28	4.00	54.69	1.48	16.26	11.83	1.51	80152.19
7	9.36	12.97	48.23	1.34	15.61	12.22	1.53	77994.08
8	13.42	2.58	58.63	0.85	17.11	11.68	1.56	82703.57
9	15.13	6.56	51.27	0.89	17.01	11.79	1.55	81547.05
10	12.59	3.33	62.01	0.51	18.92	11.47	1.55	83037.66
11	14.36	4.34	46.82	0.46	18.86	11.26	1.52	84192.17
12	13.23	12.10	47.85	0.52	18.05	11.56	1.56	81568.35
13	13.72	2.42	44.20	0.83	17.66	11.52	1.53	81516.12
14	13.96	3.05	58.95	0.85	17.04	12.43	1.53	74803.04
15	11.22	8.50	52.13	1.11	16.76	12.01	1.56	79352.89
16	14.18	12.89	60.17	0.46	18.36	11.70	1.57	80954.30
17	12.72	4.10	65.76	0.26	19.60	11.22	1.57	85020.84
18	11.37	6.06	61.18	0.38	18.72	11.59	1.56	82950.52
19	13.95	11.99	62.16	0.44	18.67	11.84	1.56	80650.58
20	13.15	14.37	54.02	0.67	19.39	10.93	1.55	87614.30
21	13.99	2.24	47.74	0.63	18.92	11.15	1.54	86188.37
22	8.82	5.09	51.28	0.50	18.50	11.43	1.54	83399.14
23	13.13	8.00	55.89	0.36	19.14	11.53	1.55	82948.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.68	7.68	56.07	1.03	17.57	11.75	1.54	81832.40
最 大 值	15.90	21.13	65.76	2.63	19.60	12.44	1.57	87614.30
發生時間	3	4	17	3	17	1		20
最 小 值	6.94	2.24	44.20	0.26	15.61	10.93	1.49	74803.04
發生時間	5	21	13	17	7	20		14
零點偏移(率)	-0.11 %	-0.05 %	-0.21 %	-0.06 %		0.03	0.00	0.00 %
全幅偏移(率)	4.46 %	0.33 %	-0.76 %	0.04 %		0.20	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 111年06月25日

備註

