

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 2020年07月08日

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
0	11.05	4.01	83.92	10.08	16.16	11.06	0.44	107735.61
1	6.38	4.07	79.29	10.16	17.37	11.15	0.40	106374.26
2	6.37	8.91	78.16	10.87	17.14	11.60	0.39	101976.14
3	12.29	2.85	82.80	10.70	15.67	11.31	0.43	102937.01
4	14.45	2.53	80.56	11.02	15.48	11.28	0.44	102700.41
5	13.75	14.12	81.94	11.05	15.49	11.07	0.45	108510.70
6	7.70	2.64	83.79	10.69	14.56	11.36	0.50	99418.58
7	11.93	4.13	91.02	11.24	14.20	12.06	0.47	92026.53
8	10.70	3.79	103.76	10.74	15.14	11.88	0.44	95018.61
9	6.83	7.18	81.20	9.91	16.08	10.97	0.44	105112.10
10	14.20	9.59	85.98	10.93	13.31	11.54	0.47	101066.39
11	22.55	無效	77.63	11.55	12.79	11.61	0.52	93326.64
12	14.61	無效	80.66	11.40	13.37	11.77	0.48	92192.30
13	7.76	3.44	94.06	10.48	16.18	11.66	0.48	93866.78
14	5.06	2.74	100.63	9.93	17.25	10.89	0.44	105588.93
15	9.74	9.11	77.86	10.62	15.82	10.87	0.42	108131.73
16	6.72	10.30	78.40	9.97	16.60	10.97	0.41	106905.33
17	5.69	2.59	76.40	9.85	16.46	11.08	0.44	107076.96
18	5.36	1.74	88.60	9.70	17.70	10.40	0.46	112598.00
19	10.47	2.46	95.32	10.10	16.67	10.48	0.52	103053.46
20	14.31	1.33	91.30	10.27	15.41	10.72	0.53	99790.04
21	10.45	8.33	75.68	9.81	15.27	10.55	0.53	100406.14
22	6.22	24.63	67.05	9.46	15.29	10.31	0.52	99068.03
23	3.50	41.56	58.02	9.11	16.74	9.92	0.51	102380.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	22	24	24	24	24	24	24
平均值	9.92	7.82	83.08	10.40	15.67	11.10	0.46	101969.20
最大值	22.55	41.56	103.76	11.55	17.70	12.06	0.54	112598.00
發生時間	11	23	8	11	18	7		18
最小值	3.50	1.33	58.02	9.11	12.79	9.92	0.38	92026.53
發生時間	23	20	23	23	11	23		7
零點偏移	-0.01 %	0.00%	-0.02 %	-0.05 %		0.02	0.00	0.00 %
全幅偏移	0.00 %	0.03%	0.07 %	0.01 %		-0.00	0.02	0.19 %
有效比率	100.00 %	91.67%	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 2020年07月08日

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
0	15.95	8.52	113.18	8.34	18.69	10.55	1.46	86399.68
1	16.32	7.00	102.28	7.97	20.03	9.74	1.42	91991.06
2	16.96	23.45	91.24	10.08	18.81	9.71	1.38	84597.52
3	19.80	24.26	91.22	8.30	17.78	9.89	1.39	79853.55
4	13.41	35.61	84.00	7.93	17.27	9.83	1.40	79336.27
5	19.21	62.76	88.35	7.96	17.11	9.82	1.40	80868.16
6	22.87	67.78	86.35	9.37	15.98	10.02	1.39	78670.23
7	14.76	4.51	93.75	7.92	19.78	9.61	1.41	80675.71
8	15.79	6.66	89.35	7.82	17.81	9.74	1.42	79153.86
9	15.18	4.53	82.50	7.66	18.94	8.96	1.42	85987.57
10	10.34	38.35	82.15	7.50	17.39	9.44	1.42	82716.89
11	8.31	79.59	84.55	7.60	17.00	9.71	1.44	73016.17
12	10.39	8.77	81.28	7.38	18.66	8.98	1.45	77728.89
13	12.90	39.89	66.65	17.91	22.83	7.20	1.44	89143.07
14	5.04	83.89	48.93	7.55	19.76	7.97	1.44	76861.57
15	6.94	無效	59.21	7.46	18.54	8.77	1.44	69599.29
16	23.11	51.23	60.78	9.23	17.94	8.31	1.43	77266.17
17	21.02	33.09	61.14	8.23	20.24	8.16	1.40	80490.55
18	13.08	44.57	57.82	7.80	22.12	7.61	1.38	85728.48
19	11.28	89.53	46.84	8.92	20.90	7.42	1.39	78544.15
20	8.19	86.09	62.64	8.94	19.32	7.27	1.40	73647.41
21	15.20	70.44	59.99	9.85	18.23	7.92	1.38	74032.90
22	22.68	27.90	58.78	10.88	18.63	8.00	1.38	79437.32
23	28.00	7.18	69.79	9.41	19.78	8.38	1.38	86115.82
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	23	24	24	24	24	24	24
平均值	15.28	39.37	75.95	8.83	18.90	8.88	1.41	80494.26
最大值	28.00	89.53	113.18	17.91	22.83	10.55	1.48	91991.06
發生時間	23	19	0	13	13	0		1
最小值	5.04	4.51	46.84	7.38	15.98	7.20	1.38	69599.29
發生時間	14	7	19	12	6	13		15
零點偏移	-0.01 %	0.00%	-0.01 %	-0.06 %		0.01	-0.00	0.00 %
全幅偏移	0.24 %	0.07%	0.06 %	0.01 %		0.02	-0.00	0.12 %
有效比率	100.00 %	95.83%	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %