

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 111年10月02日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.14	5.98	51.99	0.19	18.39	12.23	1.33	65518.45
1	11.21	4.86	51.01	0.17	18.82	11.62	1.34	69026.69
2	11.61	10.88	45.70	0.42	18.45	11.52	1.33	69647.83
3	10.29	3.17	39.88	0.12	17.70	11.70	1.32	68601.16
4	11.37	4.58	42.00	0.15	19.21	11.53	1.32	68811.01
5	15.49	5.68	35.26	0.15	20.07	10.75	1.30	83186.77
6	9.21	8.67	40.20	0.12	17.64	11.99	1.30	67045.97
7	10.96	8.69	46.02	0.14	18.16	12.36	1.30	64563.14
8	11.48	5.73	48.55	0.14	18.44	12.15	1.32	65446.25
9	11.23	1.77	36.40	0.17	21.08	10.73	1.30	73302.79
10	11.54	1.73	36.94	0.15	20.40	10.85	1.32	72613.17
11	10.32	1.38	45.68	0.16	19.91	11.12	1.31	71149.55
12	10.88	2.44	37.90	0.12	18.32	11.34	1.32	70595.59
13	12.09	1.74	40.57	0.12	19.26	11.29	1.33	70643.70
14	9.80	1.36	43.97	0.15	19.62	11.29	1.33	70352.94
15	10.30	4.77	46.46	0.17	19.61	11.33	1.32	69688.43
16	10.43	5.19	48.77	0.17	18.74	12.05	1.30	65128.13
17	9.27	19.17	66.86	0.19	18.10	13.21	1.37	57311.47
18	11.26	2.38	62.25	0.18	18.36	12.68	1.36	60948.16
19	10.12	4.85	46.94	0.12	17.52	11.71	1.31	68635.82
20	13.32	1.41	52.57	0.15	19.37	11.49	1.33	69056.53
21	10.65	1.90	47.31	0.13	18.31	11.90	1.30	66568.08
22	13.71	1.97	51.51	0.12	18.84	11.81	1.28	66767.98
23	10.78	5.45	50.23	0.13	17.56	11.87	1.28	67112.17
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.14	4.82	46.46	0.16	18.83	11.69	1.32	68405.07
最 大 值	15.49	19.17	66.86	0.42	21.08	13.21	1.75	83186.77
發生時間	5	17	17	2	9	17		5
最 小 值	9.21	1.36	35.26	0.12	17.52	10.73	1.28	57311.47
發生時間	6	14	5	3	19	9		17
零點偏移(率)	0.00 %	0.00 %	-0.01 %	0.00 %		0.03	0.00	0.00 %
全幅偏移(率)	0.16 %	-0.24 %	-1.26 %	0.44 %		0.39	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 111年10月02日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	10.30	4.62	52.23	0.18	18.67	11.06	1.43	84075.83
1	10.14	4.39	46.44	0.17	19.56	11.03	1.43	83955.89
2	9.77	8.46	51.54	0.15	17.76	11.43	1.43	82503.93
3	12.03	2.97	45.49	0.14	19.02	10.52	1.43	88949.89
4	10.92	1.15	44.57	0.14	19.65	10.69	1.43	86266.83
5	11.57	1.98	38.55	0.14	19.51	10.58	1.40	87525.47
6	9.61	3.38	43.39	0.15	18.67	10.81	1.40	81867.25
7	10.67	4.73	47.52	0.22	18.83	11.05	1.43	84514.70
8	10.85	12.05	49.07	0.14	19.66	10.31	1.44	89577.38
9	11.86	1.45	43.32	0.15	19.07	10.58	1.46	87560.24
10	11.06	1.43	51.47	0.15	19.24	10.86	1.45	84739.02
11	10.46	7.55	52.81	0.13	18.98	10.75	1.46	85838.89
12	10.98	3.39	46.31	0.13	19.13	10.51	1.48	87416.31
13	11.40	0.99	42.30	0.12	18.65	10.79	1.49	86567.27
14	11.31	1.71	42.13	0.14	19.79	10.48	1.48	88130.62
15	9.81	6.56	53.00	0.20	19.00	11.93	1.47	76905.13
16	9.87	12.63	69.12	0.20	17.31	13.64	1.52	63819.25
17	11.32	0.78	56.54	0.21	19.71	11.54	1.44	79336.07
18	12.00	4.31	49.09	0.15	18.71	10.78	1.45	86874.05
19	10.63	8.08	44.07	0.16	19.69	10.60	1.45	86214.98
20	10.15	2.49	47.78	0.16	18.28	11.60	1.43	79431.72
21	12.72	1.13	54.13	0.16	19.21	11.31	1.44	82152.01
22	11.81	1.94	45.66	0.18	17.46	11.48	1.44	81332.29
23	10.78	4.96	43.64	0.12	17.81	11.47	1.44	81200.44
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.92	4.30	48.34	0.16	18.89	11.07	1.45	83614.81
最 大 值	12.72	12.63	69.12	0.22	19.79	13.64	1.74	89577.38
發生時間	21	16	16	7	14	16		8
最 小 值	9.61	0.78	38.55	0.12	17.31	10.31	1.38	63819.25
發生時間	6	17	5	13	16	8		16
零點偏移(率)	-0.05 %	-0.00 %	-0.00 %	-0.01 %		0.05	0.00	0.00 %
全幅偏移(率)	-1.04 %	-0.31 %	-0.04 %	0.03 %		0.04	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 111年10月02日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	11.76	11.05	38.39	0.45	15.94	10.79	1.19	71709.68
1	10.74	0.83	40.71	0.40	17.23	10.92	1.18	73647.90
2	12.10	3.99	38.12	0.58	17.83	10.37	1.18	74631.45
3	11.21	4.63	36.20	0.94	16.64	10.55	1.18	73895.88
4	10.75	1.26	43.81	1.59	17.58	10.44	1.18	77500.06
5	10.04	2.09	41.20	0.97	17.10	10.75	1.18	74810.46
6	11.34	4.72	40.14	0.62	18.71	10.35	1.18	77779.24
7	6.85	9.05	29.61	0.35	16.94	10.43	1.19	68359.15
8	11.46	2.06	39.88	0.75	16.17	11.24	1.22	69649.46
9	10.84	3.53	37.93	0.36	18.87	10.23	1.20	77960.52
10	10.65	2.85	44.42	0.44	19.01	10.23	1.24	80338.27
11	10.67	1.77	47.59	0.79	16.83	10.78	1.21	76266.13
12	11.13	1.67	46.81	0.59	17.46	10.53	1.25	76263.81
13	11.03	1.10	49.43	0.64	16.99	10.79	1.25	75782.06
14	10.57	0.83	56.09	0.33	18.52	10.65	1.25	75410.68
15	8.07	7.72	67.79	0.06	17.27	12.41	1.25	62705.74
16	6.24	7.75	57.13	0.19	15.94	13.20	1.24	57726.95
17	11.32	1.85	60.30	0.22	17.00	11.65	1.20	72117.20
18	10.98	12.42	47.88	0.91	14.96	11.00	1.18	73684.40
19	11.50	1.18	46.28	1.10	17.10	10.63	1.22	75197.52
20	11.17	1.75	44.27	0.32	17.22	11.00	1.23	71759.63
21	14.38	2.21	46.77	0.95	18.00	9.95	1.18	78623.12
22	13.79	2.11	41.90	0.74	17.77	10.19	1.18	77465.44
23	16.34	6.39	38.86	1.00	17.41	10.51	1.19	75297.75
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.04	3.95	45.06	0.64	17.27	10.82	1.21	73690.94
最 大 值	16.34	12.42	67.79	1.59	19.01	13.20	1.26	80338.27
發生時間	23	18	15	4	10	16		10
最 小 值	6.24	0.83	29.61	0.06	14.96	9.95	1.17	57726.95
發生時間	16	1	7	15	18	21		16
零點偏移(率)	-0.08 %	0.00 %	-0.01 %	0.00 %		0.02	0.00	0.00 %
全幅偏移(率)	0.02 %	-0.03 %	-0.22 %	0.02 %		0.35	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								