

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月06日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.78	3.21	61.41	1.34	19.67	11.48	1.37	75498.01
1	9.15	3.68	59.53	1.35	19.66	11.43	1.36	76129.15
2	10.67	13.85	55.44	1.81	17.65	11.78	1.36	75389.47
3	10.67	3.25	60.37	1.64	18.40	11.56	1.38	76393.31
4	11.91	9.94	55.79	1.87	17.18	11.60	1.37	77036.84
5	12.33	5.68	57.96	2.12	18.08	11.63	1.33	75873.27
6	10.66	3.43	58.99	1.63	18.12	11.72	1.33	76195.62
7	9.27	5.08	59.05	1.73	17.54	12.10	1.33	73153.73
8	5.19	1.28	55.14	1.20	18.79	11.94	1.34	73917.16
9	1.12	2.18	62.13	1.21	18.44	12.21	1.41	72027.24
10	0.13	9.06	52.33	1.95	16.94	13.31	1.70	63872.97
11	5.53	0.59	56.40	1.35	19.11	11.24	1.38	76741.92
12	8.01	4.78	50.58	1.38	18.44	11.18	1.39	77797.91
13	14.23	4.17	50.13	2.20	16.57	11.80	1.36	73409.07
14	11.90	4.30	49.92	2.18	16.42	11.89	1.34	73827.05
15	10.62	4.67	52.73	1.91	16.64	11.69	1.38	75446.31
16	9.20	1.38	60.23	1.50	18.09	11.49	1.39	75710.37
17	9.52	1.44	57.04	1.50	18.12	11.35	1.38	78139.81
18	8.48	2.80	65.36	1.63	17.41	12.33	1.38	71033.47
19	8.82	1.10	56.57	1.33	18.84	11.63	1.38	76061.64
20	11.60	1.28	64.30	1.44	19.13	11.36	1.40	77335.41
21	10.05	1.65	61.02	1.41	18.45	11.55	1.41	76734.14
22	12.26	3.87	58.40	1.65	17.71	11.79	1.41	74842.89
23	10.90	3.01	60.86	1.84	17.91	11.71	1.40	75952.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.29	3.99	57.57	1.63	18.05	11.74	1.39	74938.31
最 大 值	14.23	13.85	65.36	2.20	19.67	13.31	2.05	78139.81
發生時間	13	2	18	13	0	10		17
最 小 值	0.13	0.59	49.92	1.20	16.42	11.18	1.32	63872.97
發生時間	10	11	14	8	14	12		10
零點偏移(率)	-0.01 %	-0.00 %	-0.00 %	-0.00 %		0.04	0.00	0.00 %
全幅偏移(率)	-1.29 %	-0.54 %	0.06 %	0.00 %		0.21	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 111年12月06日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	8.72	2.75	66.97	1.52	18.83	10.81	1.46	65349.52
1	8.07	7.80	62.39	1.88	19.35	10.58	1.46	65663.16
2	9.72	3.36	58.73	2.21	18.14	10.70	1.46	64921.80
3	11.24	6.24	62.59	2.64	17.10	11.08	1.46	64869.35
4	10.88	4.77	68.00	2.71	15.65	11.29	1.47	64537.23
5	9.34	3.52	60.37	2.47	16.39	11.10	1.46	64887.69
6	11.77	7.58	63.09	2.78	16.10	11.09	1.46	66599.43
7	8.65	5.65	60.03	2.76	15.69	11.30	1.47	62765.53
8	8.47	1.95	59.93	2.88	16.00	11.17	1.47	63860.62
9	10.29	3.65	61.71	2.50	16.72	10.79	1.48	66402.90
10	10.46	4.20	60.97	2.58	16.43	10.98	1.46	64853.64
11	10.93	1.42	58.63	2.63	16.30	10.82	1.47	66633.63
12	8.64	4.04	61.04	2.65	15.16	11.29	1.45	63758.34
13	15.54	5.88	63.04	5.86	14.52	11.33	1.42	63018.06
14	14.62	4.12	61.46	4.11	15.64	11.48	1.41	62002.34
15	11.34	7.38	61.26	2.80	17.34	10.58	1.41	66902.96
16	9.86	1.30	66.97	2.59	17.51	10.92	1.42	65028.07
17	10.25	1.36	59.28	2.54	16.25	11.17	1.45	65558.21
18	12.23	1.37	65.41	2.51	17.18	11.00	1.46	65607.82
19	11.95	1.32	70.32	3.64	17.75	10.98	1.44	64203.35
20	11.14	0.80	59.03	2.40	17.79	10.53	1.43	67817.71
21	10.42	1.34	59.34	2.40	16.78	10.98	1.43	64493.44
22	11.75	1.31	61.38	2.54	17.08	10.97	1.43	63410.22
23	10.70	4.35	65.63	1.91	18.59	10.44	1.42	67766.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.71	3.64	62.40	2.73	16.85	10.97	1.45	65037.99
最 大 值	15.54	7.80	70.32	5.86	19.35	11.48	1.49	67817.71
發生時間	13	1	19	13	1	14		20
最 小 值	8.07	0.80	58.63	1.52	14.52	10.44	1.39	62002.34
發生時間	1	20	11	0	13	23		14
零點偏移(率)	-0.02 %	0.00 %	-0.22 %	0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	1.98 %	-0.06 %	0.60 %	0.16 %		0.20	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月06日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.38	5.96	68.19	2.15	16.41	11.45	1.29	83497.45
1	2.53	7.09	70.64	2.18	16.68	11.76	1.30	79222.11
2	5.92	8.02	59.05	2.58	15.08	11.22	1.30	81921.78
3	8.69	8.17	58.50	2.88	15.39	10.88	1.29	83735.70
4	8.73	9.11	54.21	2.57	16.17	10.76	1.30	83272.98
5	7.86	10.67	50.92	2.52	16.91	10.24	1.30	85007.08
6	8.33	7.65	53.81	2.23	16.49	10.65	1.30	83848.97
7	8.62	2.09	59.91	2.02	16.89	10.53	1.30	86093.93
8	8.00	2.92	56.64	2.10	16.18	10.74	1.30	83964.36
9	8.99	5.23	54.01	2.30	16.00	10.51	1.30	86542.46
10	6.39	5.47	55.86	2.21	15.78	11.08	1.30	86439.49
11	9.37	4.58	57.60	2.20	16.40	10.87	1.29	88888.78
12	13.72	3.66	58.69	3.70	13.95	11.36	1.28	81435.48
13	12.93	2.95	52.61	3.45	14.14	10.96	1.28	81865.93
14	9.05	1.57	55.41	2.38	15.34	11.07	1.28	82449.11
15	10.50	14.73	53.11	2.00	16.60	10.73	1.27	85660.18
16	8.66	5.79	52.02	2.15	15.87	10.78	1.28	80309.44
17	9.19	2.01	56.96	1.86	17.44	10.57	1.30	87618.94
18	8.47	6.60	62.21	2.11	16.04	11.56	1.30	79914.52
19	9.61	5.67	64.54	2.22	16.95	11.47	1.30	80580.91
20	10.74	3.30	51.98	2.48	16.24	10.59	1.30	85013.38
21	9.68	2.40	54.66	2.64	14.71	10.98	1.28	80039.44
22	9.43	2.35	54.58	2.33	15.46	10.62	1.27	81051.46
23	10.22	2.93	59.19	2.10	16.54	10.61	1.29	86151.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.83	5.46	57.30	2.39	15.99	10.92	1.29	83521.87
最 大 值	13.72	14.73	70.64	3.70	17.44	11.76	1.33	88888.78
發生時間	12	15	1	12	17	1		11
最 小 值	2.53	1.57	50.92	1.86	13.95	10.24	1.25	79222.11
發生時間	1	14	5	17	12	5		1
零點偏移(率)	-0.04 %	0.00 %	-0.14 %	-0.01 %		0.00	0.00	0.00 %
全幅偏移(率)	1.75 %	0.20 %	-0.28 %	0.06 %		0.38	0.02	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								