

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 111年08月10日

報表日期: 111年08月10日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.26	7.30	59.42	0.33	18.85	11.75	1.57	80661.93
1	13.65	3.62	60.08	0.42	20.22	10.93	1.59	86547.66
2	15.34	4.50	60.75	0.75	18.40	11.31	1.61	84786.70
3	17.24	15.85	56.21	2.37	16.79	11.43	1.64	83392.99
4	5.51	2.32	58.65	1.37	18.99	11.32	1.65	80467.80
5	12.67	14.62	45.89	1.05	18.30	11.16	1.65	87682.75
6	12.77	11.64	60.90	0.45	19.24	11.49	1.66	81315.27
7	14.43	3.93	51.97	1.05	19.50	10.88	1.65	85216.14
8	13.35	7.11	52.75	0.47	20.75	10.83	1.63	85793.22
9	13.06	9.52	44.86	0.83	20.96	10.43	1.63	86065.57
10	13.73	1.51	71.14	0.29	21.03	10.66	1.65	85941.39
11	16.01	4.24	45.67	0.43	19.95	10.92	1.64	85494.90
12	13.43	7.45	51.86	0.35	21.89	10.00	1.63	91659.79
13	12.09	5.95	46.33	0.18	22.65	9.73	1.65	93426.06
14	12.88	2.03	43.39	0.40	20.64	10.86	1.65	86769.55
15	14.72	1.36	48.71	0.72	20.42	10.54	1.65	89379.46
16	14.58	7.38	44.96	1.61	17.48	11.17	1.65	86366.69
17	13.66	2.75	61.52	0.56	21.09	10.54	1.66	88458.91
18	13.94	1.06	58.72	0.41	20.26	10.58	1.66	86495.67
19	14.57	3.85	41.86	0.54	19.66	10.79	1.66	86351.26
20	12.55	12.37	41.82	0.73	17.76	11.36	1.65	81746.94
21	13.98	7.27	44.63	0.64	17.83	11.54	1.64	82565.99
22	14.61	14.66	44.33	0.98	18.31	10.98	1.62	87040.59
23	12.64	5.16	47.04	0.70	19.00	10.90	1.65	87638.34
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	13.49	6.56	51.81	0.73	19.58	10.92	1.64	85886.07
最 大 值	17.24	15.85	71.14	2.37	22.65	11.75	1.67	93426.06
發生時間	3	3	10	3	13	0		13
最 小 值	5.51	1.06	41.82	0.18	16.79	9.73	1.56	80467.80
發生時間	4	18	20	13	3	13		4
零點偏移(率)	-0.02 %	-0.01 %	-0.02 %	-0.01 %		0.04	0.00	0.00 %
全幅偏移(率)	-1.47 %	0.62 %	-0.49 %	0.12 %		0.01	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 111年08月10日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.56	2.97	59.24	0.13	18.19	10.99	1.51	61751.98
1	17.21	6.23	59.79	1.11	18.27	10.90	1.50	60808.46
2	13.21	2.30	60.44	0.65	17.58	10.83	1.50	61101.84
3	13.78	6.65	57.67	1.58	15.21	11.22	1.50	61143.39
4	9.99	1.41	65.14	0.52	17.56	10.83	1.51	62362.34
5	13.25	6.98	53.40	1.06	16.61	10.88	1.51	59733.04
6	14.52	8.77	56.03	0.19	19.29	10.24	1.51	62343.37
7	13.66	3.91	51.75	0.32	17.95	10.60	1.52	59601.14
8	13.42	1.22	63.76	0.14	18.23	10.93	1.51	58425.50
9	13.66	1.38	51.87	0.20	17.48	10.86	1.51	59593.75
10	11.22	11.30	58.39	0.69	16.01	11.85	1.51	54219.81
11	13.75	12.98	59.12	0.41	16.97	11.50	1.51	55743.88
12	6.87	6.15	52.36	0.16	19.21	10.80	1.52	58203.67
13	18.39	0.98	42.65	0.20	18.29	10.26	1.51	65590.52
14	9.98	7.12	42.27	0.20	18.24	10.81	1.51	62084.92
15	12.00	2.55	54.37	0.11	17.93	11.32	1.51	58364.06
16	13.98	1.03	58.40	0.12	18.94	10.40	1.52	64906.10
17	12.78	3.60	50.36	0.11	18.20	10.55	1.51	63281.32
18	13.75	2.85	53.49	0.13	18.71	10.84	1.51	61274.25
19	13.43	5.83	51.50	0.13	18.80	10.71	1.51	62515.00
20	13.50	0.60	63.03	0.12	17.86	10.73	1.51	64574.06
21	12.67	1.53	62.69	0.14	17.07	10.95	1.51	63463.74
22	13.11	3.64	59.15	0.28	16.06	11.20	1.51	61134.09
23	14.20	13.02	60.47	0.22	18.29	10.59	1.51	63264.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	13.16	4.79	56.14	0.37	17.79	10.87	1.51	61061.84
最 大 值	18.39	13.02	65.14	1.58	19.29	11.85	1.53	65590.52
發生時間	13	23	4	3	6	10		13
最 小 值	6.87	0.60	42.27	0.11	15.21	10.24	1.50	54219.81
發生時間	12	20	14	15	3	6		10
零點偏移(率)	-0.02 %	0.00 %	-0.01 %	-0.01 %		-0.05	0.00	-0.10 %
全幅偏移(率)	0.57 %	1.49 %	-0.25 %	0.25 %		-0.13	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

