

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月27日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.77	6.16	54.77	0.09	18.31	12.49	1.70	59323.20
1	10.22	7.18	47.13	0.15	19.06	11.72	1.70	64377.15
2	7.04	24.36	55.16	1.61	15.49	13.80	1.72	50586.95
3	13.54	5.97	31.19	0.76	18.20	11.92	1.71	61090.95
4	12.39	4.81	42.00	0.76	18.12	11.20	1.70	65676.17
5	15.72	4.71	45.19	1.05	16.58	11.64	1.63	64346.07
6	12.63	4.46	51.03	0.88	17.61	11.45	1.62	64796.08
7	13.18	5.63	46.59	0.84	17.34	11.49	1.64	65190.41
8	12.45	3.80	50.81	0.44	17.71	11.53	1.65	64488.78
9	12.38	3.80	61.40	0.22	18.09	11.92	1.65	62150.93
10	12.93	3.06	52.49	0.58	17.38	11.59	1.65	65047.23
11	12.80	1.75	52.22	0.30	17.14	11.79	1.67	62882.62
12	12.14	1.24	54.14	0.12	17.59	11.81	1.65	61698.49
13	12.88	1.04	54.79	0.08	18.57	11.42	1.65	64396.40
14	12.33	2.90	59.10	0.08	17.86	12.29	1.66	59372.45
15	12.82	2.59	63.47	0.11	18.71	12.03	1.67	60765.78
16	12.73	2.57	47.43	0.18	18.00	11.44	1.66	65283.51
17	10.00	9.21	56.18	0.62	16.60	12.47	1.67	58622.74
18	8.80	1.72	59.16	0.43	16.23	12.62	1.66	57367.86
19	12.36	1.46	65.68	0.31	17.07	12.42	1.68	59888.02
20	11.19	2.37	69.78	0.30	17.08	12.78	1.67	58068.07
21	12.60	0.73	60.43	0.44	17.62	11.62	1.65	65826.37
22	13.45	1.17	55.74	0.41	17.16	11.84	1.69	64474.59
23	9.11	1.57	59.55	0.28	17.07	12.27	1.69	61472.78
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.02	4.34	53.98	0.46	17.52	11.98	1.67	61966.40
最 大 值	15.72	24.36	69.78	1.61	19.06	13.80	1.80	65826.37
發生時間	5	2	20	2	1	2		21
最 小 值	7.04	0.73	31.19	0.08	15.49	11.20	1.61	50586.95
發生時間	2	21	3	13	2	4		2
零點偏移(率)	-0.02 %	-0.02 %	-0.00 %	-0.01 %		0.01	0.00	0.00 %
全幅偏移(率)	1.64 %	0.54 %	-0.89 %	0.28 %		-0.13	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 111年08月27日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	11.94	3.76	47.29	1.92	16.90	10.18	1.85	73844.46
1	11.54	3.18	50.48	2.15	16.45	10.49	1.85	72014.11
2	12.33	5.49	53.73	2.36	16.57	10.57	1.85	72750.86
3	11.40	4.21	48.87	2.15	17.53	10.09	1.87	74896.02
4	13.98	8.34	51.22	3.01	14.76	10.79	1.89	73972.40
5	15.75	4.30	49.61	6.06	13.44	10.67	1.90	70029.63
6	11.97	3.24	48.18	3.42	15.03	10.46	1.91	71611.09
7	19.74	10.01	46.17	3.57	16.26	10.18	1.81	73135.86
8	10.62	3.22	49.51	2.55	16.61	10.35	1.83	72076.39
9	12.47	4.57	48.73	1.87	17.82	10.13	1.83	72900.15
10	12.88	4.43	43.71	2.48	15.27	10.35	1.84	73383.72
11	12.53	3.71	48.02	2.58	15.09	10.45	1.81	71985.27
12	9.96	10.63	47.99	2.41	15.09	10.23	1.85	70938.67
13	13.58	1.83	60.92	2.38	15.87	10.32	1.86	71529.15
14	12.18	4.50	57.49	2.99	16.20	10.13	1.85	70746.26
15	12.21	3.10	48.50	2.81	15.33	10.62	1.85	67375.65
16	13.51	4.29	49.51	2.85	15.73	10.55	1.85	68689.56
17	11.66	1.47	49.44	2.49	15.22	10.70	1.82	69459.39
18	12.16	0.57	61.45	1.97	16.70	10.14	1.82	73056.04
19	13.67	3.45	52.28	2.25	16.60	10.30	1.83	73268.43
20	10.86	3.59	51.06	1.92	16.85	10.48	1.85	71599.50
21	12.76	2.48	50.54	2.27	15.70	10.58	1.82	72017.41
22	12.89	2.02	49.35	2.04	15.63	10.66	1.81	70408.40
23	11.64	2.18	50.54	2.06	15.82	10.47	1.84	71337.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.68	4.11	50.61	2.61	15.94	10.41	1.84	71792.73
最 大 值	19.74	10.63	61.45	6.06	17.82	10.79	1.92	74896.02
發生時間	7	12	18	5	9	4		3
最 小 值	9.96	0.57	43.71	1.87	13.44	10.09	1.79	67375.65
發生時間	12	18	10	9	5	3		15
零點偏移(率)	-0.26 %	-0.03 %	-0.07 %	0.00 %		-0.03	0.00	0.00 %
全幅偏移(率)	1.38 %	0.48 %	-0.24 %	0.14 %		0.26	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								