

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 111年11月15日

項目 單位	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO ₂ _C	#1-H ₂ O	#1-O ₂ _C	#1-OPAC	#1-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.24	5.22	51.04	0.11	20.35	11.47	1.51	60756.30
1	4.46	4.73	50.96	0.12	20.42	11.38	1.51	61631.71
2	8.69	7.72	44.15	0.53	18.59	11.50	1.51	62020.42
3	6.69	6.49	45.70	0.45	18.52	11.65	1.51	61724.43
4	2.51	6.65	44.45	0.21	18.67	11.67	1.51	60544.36
5	1.71	5.17	50.13	0.28	19.20	11.77	1.45	59873.31
6	1.53	5.40	50.16	0.32	18.76	11.88	1.41	59184.35
7	2.48	5.61	48.70	0.53	18.48	11.84	1.41	60830.13
8	2.80	5.74	48.34	0.33	18.96	11.59	1.43	70923.65
9	4.18	6.32	49.75	0.27	19.43	11.66	1.43	69871.74
10	0.34	7.14	61.79	0.13	19.14	12.32	1.44	65005.72
11	0.38	4.53	52.70	0.16	19.51	11.56	1.46	70200.84
12	2.12	3.32	44.87	0.39	18.52	11.25	1.45	72686.47
13	0.73	1.29	58.05	0.11	19.36	11.73	1.49	68922.65
14	0.09	1.24	54.33	0.08	19.16	11.66	1.47	70206.87
15	2.36	3.00	41.25	0.38	18.29	11.32	1.47	72992.10
16	7.70	16.42	40.51	1.07	17.43	11.45	1.48	69498.54
17	7.87	6.69	43.66	0.94	16.71	11.94	1.45	59171.39
18	5.47	1.98	47.69	0.68	17.07	11.76	1.41	60568.60
19	3.95	1.64	57.18	0.33	18.33	11.73	1.41	59954.42
20	5.54	1.64	53.07	0.54	18.00	11.70	1.42	60324.94
21	3.52	1.59	56.31	0.26	18.99	11.48	1.44	60992.18
22	2.11	1.29	60.26	0.09	20.57	10.98	1.46	63673.74
23	1.51	2.91	67.98	0.05	20.00	11.50	1.46	60912.21
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.54	4.74	50.96	0.35	18.85	11.62	1.46	64269.63
最 大 值	8.69	16.42	67.98	1.07	20.57	12.32	1.55	72992.10
發生時間	2	16	23	16	22	10		15
最 小 值	0.09	1.24	40.51	0.05	16.71	10.98	1.40	59171.39
發生時間	14	14	16	23	17	22		17
零點偏移(率)	-0.01 %	0.00 %	-0.03 %	-0.01 %		0.03	0.00	0.00 %
全幅偏移(率)	0.02 %	-3.96 %	-0.43 %	-1.02 %		0.02	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 111年11月15日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	5.21	7.97	62.74	2.02	16.59	11.23	1.38	83443.58
1	5.40	11.78	61.18	2.16	16.80	11.42	1.38	81213.88
2	7.50	11.43	66.07	2.72	14.96	11.56	1.38	81468.82
3	3.41	6.26	55.97	3.51	15.58	11.25	1.37	80241.24
4	2.43	8.26	57.98	1.92	16.24	11.10	1.38	82597.01
5	2.06	6.11	51.73	1.82	16.53	10.62	1.36	82190.01
6	2.40	6.08	55.34	1.79	16.96	10.90	1.36	82062.70
7	2.76	3.31	52.44	1.74	15.81	11.01	1.38	79430.15
8	3.52	2.67	52.24	1.98	16.65	10.75	1.39	83038.18
9	6.08	3.96	53.08	2.40	15.20	11.28	1.39	81031.37
10	5.77	7.97	52.80	2.41	14.99	10.96	1.38	80079.60
11	6.95	10.00	54.19	2.71	15.33	10.97	1.39	78684.21
12	9.85	1.83	52.90	3.90	16.39	10.49	1.41	82885.12
13	10.11	5.51	55.48	4.39	16.01	10.76	1.41	81576.63
14	11.34	2.08	54.22	3.04	15.90	10.73	1.40	86313.70
15	5.84	1.26	53.16	2.23	15.51	10.91	1.38	83092.70
16	8.46	1.71	55.17	2.36	16.17	10.89	1.38	83321.83
17	7.86	1.92	53.16	2.59	14.95	10.97	1.38	79948.01
18	5.02	2.33	56.48	2.31	15.74	10.92	1.38	82438.53
19	6.42	1.31	57.28	2.30	16.51	10.87	1.38	83793.87
20	6.19	1.83	57.14	2.73	15.01	11.06	1.38	82224.66
21	9.01	1.81	55.70	2.86	15.96	10.72	1.38	85001.99
22	8.76	2.62	57.05	2.59	16.58	10.85	1.38	83711.42
23	8.51	2.77	54.10	2.39	17.89	10.34	1.37	86688.85
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.29	4.70	55.73	2.54	16.01	10.94	1.38	82353.25
最 大 值	11.34	11.78	66.07	4.39	17.89	11.56	1.42	86688.85
發生時間	14	1	2	13	23	2		23
最 小 值	2.06	1.26	51.73	1.74	14.95	10.34	1.33	78684.21
發生時間	5	15	5	7	17	23		11
零點偏移(率)	-0.02 %	-0.05 %	-0.11 %	-0.00 %		-0.03	0.00	0.00 %
全幅偏移(率)	-0.88 %	-2.67 %	0.06 %	-1.52 %		0.33	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								