

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 111年09月06日

報表日期: 111年09月06日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.33	2.49	59.59	0.19	18.60	12.97	1.58	53608.89
1	11.29	3.47	42.48	0.17	17.80	12.80	1.60	55168.09
2	12.89	7.67	48.91	0.16	18.82	12.54	1.60	56863.54
3	13.21	1.59	33.56	0.12	19.32	11.05	1.59	67262.86
4	14.59	2.89	33.61	0.09	19.25	11.30	1.59	64966.30
5	13.30	2.97	48.38	0.13	19.34	11.77	1.52	64472.55
6	13.03	3.73	55.69	0.17	19.77	12.14	1.51	59178.38
7	12.47	2.79	45.76	0.13	19.88	11.38	1.49	64113.66
8	13.81	1.49	46.28	0.13	19.81	11.07	1.48	66196.12
9	11.88	6.85	43.77	0.10	17.31	12.25	1.51	59562.30
10	10.99	1.97	54.82	0.15	18.83	11.99	1.51	59970.13
11	13.77	1.62	47.75	0.11	18.19	11.92	1.50	61008.16
12	12.21	2.29	45.16	0.11	18.09	11.96	1.50	60714.94
13	12.57	2.61	43.18	0.12	18.41	11.85	1.51	61608.54
14	12.46	1.46	55.70	0.15	18.85	12.08	1.51	61232.54
15	14.24	3.14	57.29	0.14	19.08	12.02	1.51	61651.88
16	14.48	3.96	59.16	0.13	19.09	11.73	1.51	63455.92
17	11.59	2.96	53.39	0.15	19.69	11.41	1.51	64295.26
18	12.36	5.15	49.03	0.12	17.84	11.94	1.51	61445.10
19	11.63	4.36	53.89	0.14	18.35	12.17	1.51	59876.71
20	12.80	6.51	45.41	0.09	17.53	11.73	1.49	62185.76
21	9.63	4.84	66.68	0.17	18.18	12.61	1.49	56474.89
22	12.67	3.23	47.66	0.16	19.18	11.78	1.49	62588.47
23	12.64	2.59	58.71	0.19	19.61	11.96	1.51	62430.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.49	3.44	49.83	0.14	18.78	11.93	1.52	61263.80
最 大 值	14.59	7.67	66.68	0.19	19.88	12.97	1.62	67262.86
發生時間	4	2	21	0	7	0		3
最 小 值	9.33	1.46	33.56	0.09	17.31	11.05	1.46	53608.89
發生時間	0	14	3	4	9	3		0
零點偏移(率)	0.00 %	-0.01 %	-0.08 %	-0.01 %		0.02	0.00	0.00 %
全幅偏移(率)	0.35 %	-0.43 %	-0.35 %	0.13 %		-0.01	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 111年09月06日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO ₂ _C	#2-H ₂ O	#2-O ₂ _C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.95	3.18	38.08	0.21	18.62	11.77	1.59	78085.20
1	10.82	11.67	53.41	0.20	17.17	12.87	1.57	71078.86
2	13.05	4.91	48.94	0.17	19.69	10.65	1.57	87430.81
3	12.88	0.81	45.80	0.11	20.11	10.62	1.57	86984.15
4	13.77	3.38	47.21	0.14	18.32	10.68	1.57	88291.78
5	12.37	1.47	51.82	0.15	17.92	11.45	1.57	82300.92
6	9.20	1.37	44.35	0.16	18.83	10.73	1.51	75538.41
7	12.54	2.31	55.44	0.18	18.90	11.34	1.50	82659.23
8	12.38	7.53	55.53	0.11	17.08	11.08	1.47	86669.86
9	13.07	2.11	65.16	0.19	16.59	11.95	1.46	80188.30
10	14.03	1.28	63.92	0.12	17.28	12.05	1.46	79115.68
11	10.97	2.22	63.08	0.16	16.94	12.23	1.51	77163.12
12	11.26	10.58	56.73	0.12	16.56	12.15	1.53	77932.88
13	14.63	2.91	58.04	0.37	15.71	11.88	1.50	80868.41
14	11.27	2.61	64.07	0.29	15.71	12.30	1.51	77324.33
15	19.73	2.06	67.84	0.86	17.01	11.62	1.51	81523.52
16	15.74	5.28	61.47	0.28	16.14	11.93	1.50	79741.39
17	15.32	2.21	69.97	0.12	17.05	11.55	1.50	82375.46
18	12.39	4.99	71.65	0.32	15.30	12.09	1.50	78643.97
19	13.02	7.57	52.95	0.41	16.38	11.70	1.50	82492.47
20	13.19	5.95	48.62	0.18	17.07	11.23	1.50	86111.19
21	13.01	2.48	46.84	0.11	16.02	11.62	1.49	82583.31
22	12.45	2.16	49.03	0.12	16.83	11.58	1.48	82269.26
23	12.68	3.30	70.21	0.13	16.62	12.36	1.48	76134.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.95	3.93	56.26	0.22	17.24	11.64	1.51	80979.48
最 大 值	19.73	11.67	71.65	0.86	20.11	12.87	1.59	88291.78
發生時間	15	1	18	15	3	1		4
最 小 值	9.20	0.81	38.08	0.11	15.30	10.62	1.44	71078.86
發生時間	6	3	0	3	18	3		1
零點偏移(率)	-0.21 %	-0.03 %	-0.02 %	-0.01 %		0.03	0.00	0.00 %
全幅偏移(率)	0.34 %	-0.40 %	0.02 %	0.05 %		-0.05	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 111年09月06日

[illegible]